

DISPLAY

MasterCase can use any terminal or display of the PST series to signal the operating status of the control parameters. In normal operating conditions, in accordance with the configuration of the parameters A, 1, 7, the temperatures of the present probes are displayed.
Warning: The remote display (code PST00V100) only works if a terminal is also connected (code PST00R300 or PST00LR200).

ALARMS AND SIGNALS

The MasterCase series instruments can automatically detect the main malfunctions that are signalled like the following:
 • the display of the corresponding alarm code.
 In particular, the instrument alternately displays the alarm code and the temperature read by the probe. In case of more contemporary alarms, these are displayed in succession, alternating with the temperature.
 • for some alarms the internal buzzer, if present and the alarm relay are activated.

Pressing the button silences the buzzer and de-energises the alarm relay, while the alarm code disappears only when the causes of the alarm are no longer present.
 The alarm codes are shown in the table below:

CODE	BUZZER and AUX relay	DESCRIPTION	MODELS featured
E	active	control probe error	ALL
E1	not active	room probe error (S1)	ALL
E2	not active	roof probe error (S2)	ALL
E3	not active	product probe error (S3)	ALL
E0	not active	display interface probe error (being displayed)	ALL
IA	active	immediate external alarm (from digital input)	ALL
IA	active	delayed external alarm (from digital input)	ALL
LO	active	low temperature alarm	ALL
HI	active	high temperature alarm	ALL
EE	not active	data saving error	ALL
HA	active	alarm type HA (HACCP)	ALL
HF	active	alarm type HF (HACCP)	ALL
Ed	not active	defrost ended for timeout	ALL
Ed	not active	port switch error (port open timeout)	ALL
ld	active	light setting alarm (from digital input)	ALL
CCM	active	case clean management	ALL
Edc	active	communication alarm with driver board	only MGE0000020
Ed1	active	driver temperature probe alarm (Tsh)	only MGE0000020
Ed2	active	evaporation pressure probe alarm (PE)	only MGE0000020
L01	active	probe S1 minimum temperature alarm	ALL
dF	not active	defrost running	ALL
IC	not active	clock alarm (RTC)	models with RTC
MA	not active	lost contact with the Master	Slave units
oX (X=1...5)	not active	Slave X not communicating	Master units
oX (X=1...5)	active	Slave X in alarm	Master units
oX (X=1...5)	not active	download to Slave X failed	Master units

OPERATION INDICATION ON THE KEYPAD AND BUTTON COMMANDS

On terminal PST Large (see fig. 3a):
 1 HACCP signal and reset (red LED), button pressed for 5 seconds.
 2 LIGHT signal and activation (yellow LED), button pressed for 1 second.
 3 ON/OFF signal and activation (green LED), button pressed for 5 seconds.
 4 AUX signal and activation (yellow LED), button pressed for 1 second.
 5 CONTINUOUS-CYCLE signal and activation (green LED), button pressed for 5 seconds.
 6 COMPRESSOR ON signal (green LED), LIGHT activation, button pressed for 1 second.
 7 DEFROST signal and activation (yellow LED), button pressed for 5 seconds.
 8 Buzzer signal and silencing and relay ALARM (red LED).
 6 + 7 CONTINUOUS-CYCLE, button pressed for 5 seconds.
 The blinking status means that the corresponding function is delayed by a timed routine.
 The buttons 6, 7, 8 are used for the display and parameter set functions.
 On the PST Small terminal (see fig. 3b):
 6 Compressor ON signal (green LED), LIGHT activation, button pressed for 1 second.
 7 DEFROST signal and activation (yellow LED), button pressed for 5 seconds.
 8 ALARM signal and silencing (red LED).
 6 + 7 CONTINUOUS-CYCLE, button pressed for 5 seconds.

MANUAL DEFROST

Besides the automatic defrost, it is possible to activate a manual defrost, (if the corresponding activation conditions exist), pressing for 5 seconds.

ON/OFF BUTTON

Pressing for 5 seconds, it is possible to activate/deactivate the controller.
 When the controller is deactivated is in a standby condition, and all the outputs and inputs are inactive.

HACCP FUNCTION

This controller complies with the HACCP Laws in force, since it allows the continuous monitoring of the temperature, signalling if any of the maximum thresholds are exceeded for a set time (alarm with code HA) and recording the day - hour - min of the event.
 This function works even without power supply. In this case, this alarm is set using the parameters AH, Ad and t (Ad=t= HACCP activation alarm delay), signalling the code HF when power supply returns.

PROGRAMMING WITH THE HARDWARE KEY

If the hardware key (code PSCP2KE100) is used to program the instrument, the operation must be performed only with the MasterCase not powered (230 Vac terminals disconnected) and, for models MGE0000020, with the driver board for electronic valves powered (24 Vac terminals).

SET POINT (operating temperature)

- pressing the SET button for one second, the set point value appears flashing;
- use the UP or DOWN buttons to increase or decrease the value;
- pressing the button again confirms the new value.

ACCESS AND MODIFICATION OF THE FREQUENT PARAMETERS (F type and C type)

- pressing for 5 seconds PP is displayed (in case of alarm, first silence the buzzer);
- press and then or until 22 is displayed (PASSWORD); press to confirm (only for type C parameters);
- using or scroll through the parameters up to reaching the one whose value has to be modified;
- press SET to display the associated value;
- use or to modify its value;
- press to temporarily confirm the new value, then display its code.

Storage of the new values: after having set the values for each parameter press at least 5 seconds and exit the "PARAMETERS MODIFICATION" procedure. Do not switch off the controller; at least for 20 seconds for the real storage. For liming parameters only: switch off and switch on the controller in order to make them immediately effective (without waiting for the following cycle).
 To exit without modifying the parameters: do not press any button for at least 30 seconds (TIME-OUT OUTPUT).

LIST OF PARAMETERS

Parameter	Type	Min	Max	U.M.	Def	LAN
PP PARAMETERS PASSWORD	F	00	199	-	22	
PS LOG PASSWORD	F	00	199	-	44	
PD DOWNLOAD PASSWORD	F	00	199	-	66	
1 PROBE PARAMETERS						
/2 probe measurement stability	C	1	15	-	1	
/4 virtual probe (average between probe 1 and probe 3) (0= S1, 100= S3)	C	0	100	-	0	*
/6 decimal point enabling (0= no, 1= yes)	C	0	1	flag	1	*
/7 remote display management (only if a user terminal is connected) 0= absent 1= ambient probe (S1) 2= defrost probe (S2) 3= product probe (S3) 4= virtual probe	C	0	5	flag	0	*
/8 S3 probe calibration	C	-20.0	20.0	°C	0.0	
/9 defrost with product probe as well 1= probe 3 is used as end defrost probe	C	0	1	flag	0	*
A present probe						
0= defrost probe and product probe absent						
1= defrost probe absent and product probe present						
2= defrost probe present and product probe absent						
3= defrost probe and product probe present						
4= control probe "set" by the Master (in the Slave)						
/C regulation probe calibration	F	-20.0	20.0	°C	0.0	
/d defrost probe calibration	C	-20.0	20.0	°C	0.0	*
/f user interface management 0= absent 1= ambient probe (S1) 2= defrost probe (S2) 3= product probe (S3) 4= virtual probe 5= interface module probe	C	0	5	flag	0	*
A ALARM PARAMETERS						
A0 alarm return and fan activation differential	C	0.0	20.0	°C	2.0	*
A1..5 digital input configuration 0= disabled 1= immediate external alarm 2= delayed external alarm 3= enable defrost from external contact 4= start defrost from external contact 5= port switch 6= Remote ON/OFF 7= curtain switch 8= duty setting activation 9= port switch with compressor ON 10= cabinet cleaning management (C.C.M.)	C	0	10	-	0	*
A7 alarm delay from digital input (A1...A5= 2)	C	0	180	min	0	*
AB virtual digital input configuration (see A1...A5)	C	0	10	-	0	*
Ad temperature alarm delay	C	0	180	min	0	*
AH high temperature alarm: indicates the max. variation with respect to the set-point. AH= 0 excludes the high temperature alarm	F	0	20.0	°C	0.0	*
AL low temperature alarm: indicates the max. variation with respect to the set-point. AL= 0 excludes the low temperature alarm	F	0	20.0	°C	0.0	*
Ar enable remote Slave alarm signal on the Master (1= remote alarms enabled on the Master)	C	0	1	flag	1	
e COMPRESSOR PARAMETERS						
c0 regulat. starting delay at the start-up of the instrument	C	0	15	min	0	*
c1 compressor running time between 2 successive operations	C	0	15	min	0	*
c2 minimum compressor shut down time	C	0	15	min	0	*
c3 minimum compressor running time	C	0	15	min	0	*
c4 safety control (duty Cycle Setting) 0= always OFF, 100= always ON	C	0	100	min	0	*
c6 temperature alarms exclusion-time after continuous cycle	C	0	15	ore	2	*
c8 delay between valve opening and start-up of the compressor	C	0	120	s	5	*
cc continuous cycle duration	C	0	15	ore	4	*
ed DEFROST PARAMETERS						

Parameter	Type	Min	Max	U.M.	Def	LAN
d0 defrost type 0= heater: it ends for temperature and/or time-out 1= hot gas: it ends for temperature and/or time-out 2= heater: it ends for time-out 3= hot gas: it ends for time-out	C	0	3	flag	0	*
d2 LAN defrost command type (only start: t= start - s= stop) 0= compressor running time with ambient temperature below 1 °C before forcing a defrost	C	0	1	flag	1	*
d3 compressor running time with ambient temperature below 1 °C before forcing a defrost	C	0	192	hours	0	*
d4 defrost at the start-up of the instrument (0= no, 1= yes)	C	0	1	flag	0	*
d5 defrost delay at the start-up of the instrument or from digital input	C	0	180	min	0	*
d6 interface module and remote display management during defrost: 0= display stays ON, The temperature display alternates with the symbols "dF" on both displays 1= temperature not shown on both displays	C	0	1	flag	0	*
d7 enable step defrost (0= no, 1= yes)	C	0	1	flag	0	*
d8 high temper. alarm exclusion time after defrost and if A4 or A8= 5 alarm exclusion time from the door opening	F	0	15	hours	1	*
d9 defrost priority on the compressor protection (0= no, 1= yes)	C	0	1	flag	0	*
dd dripping time after defrost	F	0	15	min	2	*
dl interval between two defrosts (activated for defrost without RTC)	F	0	192	hours	8	*
dM time between two successive cleanings	C	1	999	hours	1	*
dPM cleaning duration	C	0	60	min	0	*
dP max. defrost duration	F	1	180	min	30	*
dI end defrost temperature	F	-50.0	30.0	°C	4.0	*
F FAN PARAMETERS						
F0 fan management: 0= fans always ON, specific phases excluded F2, F3 and Fd 1= thermostat-controlled fans in accordance with the absolute set point F1	C	0	1	flag	0	*
F1 fan start-up absolute set point	F	-40.0	50.0	°C	5.0	*
F2 fans OFF when compressor OFF 0= no, 1= yes active with F0= 0	C	0	1	flag	1	*
F3 fans OFF during defrost 0= no - fans still during dripping (dd) 1= yes 2= no - fans ON during dripping too (dd) active for each F0 value	C	0	2	flag	1	*
Fd fan OFF after dripping	F	0	15	min	1	*
Hd OTHER PARAMETERS						
H0 serial address	C	1	199	-	1	*
H1 remote ir control enabling/disabling	C	0	1	flag	0	*
H2 remote ir control code enabling	C	0	99	-	0	*
H3 enabling ON/OFF from keyboard	C	0	1	-	1	*
H4 enabling ON/OFF from supervisor	C	0	1	-	0	*
H5 AUX1 configuration: 0= disabled 1= compressor 2= master/slave network compressor 3= light and/or curtains 4= fans 5= hot wires 6= alarm 7= defrost 8= independent defrost on 2nd evaporator with probe S3 (see param. /9) 9= solenoid valve	C	0	9	flag	0	*
H6 configuration AUX2 (for values see H5)	C	0	9	flag	5	*
H7 compressor outlet configuration 1= compressor 2= master/slave network compressor	C	1	2	-	1	*
LAN PARAMETERS						
In configuration of the single unit as Master (In= 1) or Slave (In= 0)	C	0	1	-	0	*
Sn slave number (0= LAN not present)	C	0	5	-	0	*
r REGULATION PARAMETERS						
r1 minimum set allowed to the user	C	-50.0	r2	°C	-50.0	*
r2 maximum set allowed to the user	C	r1	90.0	°C	90.0	*
r3 Ed alarm enabling (time out defrost) 0= no; 1= yes	C	0	1	flag	0	*
r4 automatic variation of the night-time set-point (curtain switch closed)	C	-20.0	20.0	°C	3.0	*
r5 min. max. temperature monitoring enabling (0= no, 1= yes)	C	0	1	flag	0	*
r6 night-time variation with third probe S3 (0= night regulation with the virtual probe; 1= night with lowered curtain, regulation with product probe)	C	0	1	flag	0	*
rd regulator differential (hysteresis)	F	0.1	20.0	°C	2.0	*
rH max. temp. measured during <r>	C	-	-	°C	-50.0	*
rL min. temp. measured during <r>	C	-	-	°C	90.0	*
rI min. and max. temperature measuring interval	C	0	999	hours	0	*
SET POINT						
S1 temperature set point	F	r1	r2	°C	-20.0	*
SIn configuration of the single unit as Master (In= 1) or Slave (In= 0)	C	0	2	flag	0	*
hSn night-time set point mode	C	0	23	hours	0	*
hSd night-time set point end time	C	0	23	hours	0	*
SL1 probe S1 minimum temperature absolute value SL1= 90 °C function disabled	C	-50.0	90.0	°C	90.0	*
t HACCP PARAMETERS						
t HACCP alarm delay (0= disabled)	C	0	180	min	0	*
IA HACCP alarm type: 0 no alarms; 1 HA alarm; 2 HF alarm	C	0	2	flag	0	*
IO last HACCP alarm: day	C	0	7	day	0	*
IH last HACCP alarm: hours	C	0	23	hours	0	*
IW last HACCP alarm: minute	C	0	59	min	0	*
It max. temperature sensed during HACCP alarm	C	-50.0	90.0	°C	-50.0	*
IE HACCP alarm duration	C	0	240	hours	0	*
to HACCP alarms reset	C	0	1	flag	0	*
P VALVE PARAMETERS						
P1 valve model (0= CAREL E'V'P; black stator; 1= new CAREL E'V'A e' E'V'B-red stator)	C	0	1	-	1	*
P2 neutral zone	C	0	10.0	°C	0.0	*
P3 superheat set point	C	0.0	25.0	°C	8.0	*
P4 amplification factor PID	C	0.1	100.0	-	5.0	*
P5 integration factor PID	C	0	250	s	80	*
P6 differential factor PID	C	0.0	100.0	-	0.0	*
P7 activation threshold for the low superheat protection	C	-10.0	P3	°C	4.0	*
P8 integration factor for the low superheat protection	C	0	255	s/10	150	*
PA enable transmission Master to slave probe (only in the Master)	C	0	1	flag	0	*
Pb pressure probe value from Master (in the Slave)	C	0	1	flag	0	*
Pc pressure probe alarm delay	C	0	255	min	5	*
PH gas type 0= R134a 1= R22 2= R404a 3= R410a 4= R407c 5= R507 6= R290 7= R600 8= R600a 9= R717 10= R744 11= R1270	C	0	11	-	2	*
PI evaporation pressure probe type 0= 500 mV/-1013 mbarg 4500 mV/4158 mbarg (TEXAS 0-75psia) 1= 500 mV/-1013 mbarg 4500 mV/9329 mbarg (TEXAS 0-150psia) 2= 500 mV/0 mbarg 4500 mV/34474 mbarg (TEXAS 0-500psia)	C	0	2	-	0	*
OSH overheating offset	C	0.0	60.0	-	0.0	*
Phr enable high refresh valve parameters on supervisor (0=1min.; 1=1 s)	C	0	1	flag	0	*
PM1 MOP threshold (saturated pressure temperature)	C	-50.0	60.0	°C	60.0	*
PM2 integration factor during MOP function (closing valve)	C	0	255	s	100	*
PM3 MOP function delay	C	0	255	s	2	*
PM4 maximum superheated gas temperature	C	-50.0	80.0	°C	80.0	*
Po1 superheat (read only parameter)	C	-	-	°C	-	*
Po2 percentage open position valve (read only parameter)	C	0	100	%	-	*
Po3 superheat Temperature Sensor (read only parameter)	C	-	-	°C	-	*
Po4 evaporation saturated temperature (read only parameter)	C	-	-	°C	-	*
PRa enable opening recovery steps	C	0	1	Flag	1	*
PSb stand-by position (step number)	C	0	3200	steps	80	*
RTCP PARAMETERS						
d1 day of the first defrost (see Tab. 1)	C	0	10	-	0	*
t1 hour of the first defrost	C	0	23	hours	0	*
m1 minute of the first defrost	C	0	59	min	0	*
d2 day of the second defrost (see Tab. 1)	C	0	10	-	0	*
h2 hour of the second defrost	C	0	23	hours	0	*
m2 minute of the second defrost	C	0	59	min	0	*

d8 day of the eighth defrost (see Tab. 1)	C	0	10	-	0	*
h8 hour of the eighth defrost	C	0	23	hours	0	*
m8 minute of the eighth defrost	C	0	59	min	0	*
td current week day	F	1	7	day	1	*
th current hour	F	0	23	hours	0	*
t' current minute	F	0	59	min	0	*