


# pLoads

Energy control solution

# CAREL



**ENG** User manual

**→ LEGGI E CONSERVA  
QUESTE ISTRUZIONI ←**  
**→ READ AND SAVE  
THESE INSTRUCTIONS ←**

Integrated Control Solutions & Energy Savings



# Content

<b>1. INTRODUCTION</b>	<b>5</b>
<b>2. USER INTERFACE</b>	<b>6</b>
2.1 Display.....	6
<b>3. SYSTEM ARCHITECTURE</b>	<b>8</b>
<b>4. MAIN MENU – FUNCTION TREE</b>	<b>9</b>
<b>5. USER FUNCTIONS</b>	<b>11</b>
5.1 Clock setting.....	11
5.2 General scheduler setting.....	11
5.3 Energy scheduler configuration.....	12
5.4 Exceptions to general scheduler.....	12
5.5 Scheduler setting for each load.....	13
5.6 Load cut-off configuration.....	14
<b>6. INPUT/OUTPUT TABLE</b>	<b>16</b>
<b>7. INSTALLER FUNCTIONS</b>	<b>17</b>
7.1 Load installation.....	17
7.2 Pulse counter installation.....	17
7.3 Energy meter installation.....	19
7.4 Supervisor installation.....	20
7.5 General settings.....	21
7.6 Wireless network installation.....	22
7.7 Description of the terminals.....	24
7.8 Electrical connections.....	26
<b>8. OPERATING LOGIC</b>	<b>29</b>
8.1 Scheduler.....	29
8.2 Load cut-off.....	30
8.3 Override loads.....	33
8.4 Control interaction.....	34
<b>9. PARAMETERS TABLE</b>	<b>35</b>
<b>10. SUPERVISOR TABLE</b>	<b>47</b>
<b>11. ALARM TABLE</b>	<b>56</b>

## 12. PLOADS FEATURES

57

12.1 Installation warnings - intended environments and connection.....	57
12.2 Uploading the application program.....	58
12.3 Power supply .....	59
12.4 Technical specifications.....	59
12.5 Other features.....	61
12.6 Dimensions .....	62

**IMPORTANT WARNINGS**

The CAREL product is a state-of-the-art device, whose operation is specified in the technical documentation supplied with the product or can be downloaded, even prior to purchase, from the website [www.carel.com](http://www.carel.com). The customer (manufacturer, developer or installer of the final equipment) accepts all liability and risk relating to the configuration of the product in order to reach the expected results in relation to the specific installation and/or equipment. The failure to complete such phase, which is required/indicated in the user manual, may cause the final product to malfunction; CAREL accepts no liability in such cases. The customer must use the product only in the manner described in the documentation relating to the product. The liability of CAREL in relation to its products is specified in the CAREL general contract conditions, available on the website [www.carel.com](http://www.carel.com) and/or by specific agreements with customers.



READ CAREFULLY IN THE TEXT

**ATTENTION:**

Separate as much as possible the probe and digital input signal cables from the cables carrying inductive loads and power cables to avoid possible electromagnetic disturbance. Never run power cables (including the electrical panel wiring) and signal cables in the same conduits.

**DISPOSAL OF THE PRODUCT**

The appliance (or the product) must be disposed of separately in accordance with the local waste disposal legislation in force

All trademarks hereby referenced are the property of their respective owners. CAREL is a registered trademark of CAREL INDUSTRIES Hqs in Italy and/or other countries.

© CAREL INDUSTRIES Hqs 2013 all rights reserved

*CAREL reserves the right to modify the features of its products without prior notice.*

# 1. INTRODUCTION

The pLoads device can handle several different functions, depending on system requirements:

1. load scheduler;
2. load cut-off;
3. energy meter collection;
4. consumption measurement (energy, water di gas or general loads).

All these functions can be used at the same time.

The different connection modes are illustrated below.

## 1. Load scheduler



Fig. 1.a

## 2. Load cut-off




Fig. 1.b

## 3. Energy meter collection




Fig. 1.c

## 4. Consumption measurement




Fig. 1.d







## Versions available

The controller is available in two versions, which differ in terms of the number of I/Os and communication ports available (for details see the input/output table):

Hardware type	Description	CAREL code
Compact	Built-in display + USB + RS485 optoisolated	PL0550X30U000
Large	Built-in display + USB + RS485 built-in optoisolated	PL0550L30UB00

## 2. USER INTERFACE

pLoads features the pGD1 "built-in" terminal as the user interface. This device features the following buttons:

	Alarm	displays the list of alarms;
	Prg	accesses the main menu tree;
	Esc	returns to the previous screen;
	Up	scrolls a list upwards or increases the value shown on the display;
	Down	scrolls a list downwards or decreases the value shown on the display;
	Enter	enters the selected submenu or confirms the set value.

Tab. 2.a

### 2.1 Display

#### Main screen




Fig. 2.a








①	date, weekday and time;
②	type of current day;
③	current power in kW, energy in kWh and percentage of power in relation to load cut-off threshold;
④	load status (7 possibilities).

Tab. 2.b



This is the screen displayed during normal unit operation: from any other menu press ESC until reaching this screen.

The following icons may be displayed in the loads area (④):

	the load is on;
	the load is off;
	the load has been cut off;
	the load is on from supervisor;
	the load is off from supervisor;
	the load is on from digital input;
	the load is off from digital input.

### Alarm screens

If an alarm is active, the red LED under the ALARM button flashes.





Fig. 2.b

5	alarm code;
6	alarm description;
7	alarm number;
8	total number of active alarms.

Use the arrows (UP and DOWN) to scroll the list of alarms; at the end of the list, pressing ENTER on the special screen directly accesses the alarm log.

 For details on the alarms, see the alarm table, chapter 11.

### Parameter display and editing screens

To access these screens, from the main screen press PRG to enter the menu list: scroll the menus using the UP and DOWN buttons and press ENTER to select the desired menu (see the function tree).





Fig. 2.c

9	name of the function edited on the screen
10	screen index
11	editable parameter
12	parameter name.

 Note: editable fields feature numeric values or upper case letters.

### 3. SYSTEM ARCHITECTURE

pLoads, as illustrated in chapter 1, Presentation, is a device that manages several functions. For greater system flexibility, pLoads can also integrate wireless devices. The flexibility of the architecture proposed in fact allows more complex installation requirements to be met, in which the energy, water and gas meters are often located quite some distance apart, and thus serial connection over an RS485 network is not always practical. The diagram shown below illustrates a typical installation in which the energy meters are connected to the pLoads controllers over the wireless network. The diagram highlights the connections for pLoads Large, however the same also apply to the Compact model.




Fig. 3.a

DEVICE	ADDRESS NETWORK Modbus® RS485	CAREL CODE
Access point	1	WS01AB2M20
Energy meter	2...13	MT300W1100 (M TOPZD0000, user interface)
Pulse counter CI	31, 32	WS01E02M00
RB Router Bridge	-	WS01RB2M20



**Important:**

- The addresses of the energy meter must be consecutive, even if the RB Router Bridge is used
- The address of the AP Access Point must always be 1.
- The addresses available for the energy meters are always between address 2 and address 13.
- The address of the main energy meter (used to manage load cut-off) is always 2.
- The addresses of the CI wireless pulse counters must be 31 and 32.
- If the wireless network includes an RB Router Bridge, all the energy meters should be connected to one or more RB Router Bridge device. Energy Meters and Access Points cannot coexist on the same RS485 line, as the stop bits are not always compatible between these devices. This is true, for example, for the 'CAREL emeter3'; consequently, check compatibility with the energy meters available in the network and managed by the pLoads controllers.
- For further details on operation of the CAREL wireless system, see manual +0300030EN and quick guide cod. +0400030EN.




4. MAIN MENU – FUNCTION TREE

Main menu		Settings menu (with password)	
A.	General On-Off		
B.	Unit status		
	Settings	C.	Clock
	LogOut	D.	General configuration
		E.	Load configuration
		F.	Other

Tab. 4.a

**Note:** the settings menu is accessed after entering a 4-digit password (user and manufacturer). There are two types of password: installer and user. The installer password allows read/write access to the parameters, while the user password gives read-only access. These passwords can be set on the corresponding screens.

**Note:** the menu structure is reflected by the screen index. See the following example:



When selecting the following item in the menu:

C. Clock

the letter of the original menu will be shown at the top right of the screen.

**Note:** after entering the user/installer password, the LogOut function will be shown on the main menu. The password will need to be entered again after selecting LogOut or in any case after 10 minutes of no activity; it will be necessary a new entering.

Password:

Mask index	Display description	Description	Default	UM	Values
---	Insert password	Password for the access level management	1234: User 1234: Manufacturer	---	0...9999





Fig. 4.a

## 5. USER FUNCTIONS

The control allows a time scheduling with switching on and off of loads; it is active when the unit is ON from display or digital input. You can notice that the scheduler has been disabled from the main screen:

Scheduler activated






Scheduler deactivated






### 5.1 Clock setting

The user interface can be used to set the general scheduler and the current time.




The date format, current day and time can be set. In addition, on the next screen, C02, automatic daylight savings changeover can be set.

### 5.2 General scheduler setting



Four types of "days" are available (Ordinary, Special, Short and Closing). The opening time and closing time can be set for each type of day. Minimum setting resolution is 1 minute.



Select the type of day for each day of the week, from those available as set previously.

### 5.3 Energy scheduler configuration

To use pLoads as a load cut-off device, 'power', 'energy' or 'apparent power' thresholds can be set, and are selected automatically by the scheduler throughout the day. This is done on the screens provided, used to set up to six power, energy or apparent power thresholds for each hour of the day. The table below shows how the different thresholds can be set over the 24 hours of the selected day. For further details, see paragraph 8.2 'Load cut-off' and 5.6 'Load cut-off configuration'.

	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
Monday	T1	T1	T1	T1	T1	T1	T1	T2	T2	T2	T2	T2	T2	T2	T2	T2	T2	T3	T3	T3	T3	T3	T4	T4
Thursday	T1	T1	T1	T1	T1	T1	T1	T2	T2	T2	T2	T2	T2	T2	T2	T2	T2	T3	T3	T3	T3	T3	T4	T4
Wednesday	T1	T1	T1	T1	T1	T1	T1	T2	T2	T2	T2	T2	T2	T2	T2	T2	T2	T3	T3	T3	T3	T3	T4	T4
Thursday	T1	T1	T1	T1	T1	T1	T1	T2	T2	T2	T2	T2	T2	T2	T2	T2	T2	T3	T3	T3	T3	T3	T4	T4
Friday	T1	T1	T1	T1	T1	T1	T1	T2	T2	T2	T2	T2	T2	T2	T2	T2	T2	T3	T3	T3	T3	T3	T4	T4
Saturday	T3	T3	T3	T3	T3	T3	T3	T4	T4	T4	T4	T4	T4	T4	T4	T4	T4	T5	T5	T5	T5	T5	T6	T6
Sunday	T3	T3	T3	T3	T3	T3	T3	T4	T4	T4	T4	T4	T4	T4	T4	T4	T4	T5	T5	T5	T5	T5	T6	T6

```

Energy band C05
Day: MONDAY
Copy to: MONDAY N
00-05T6 T6 T6 T6 T6 T6
06-11T5 T5 T5 T4 T4 T4
12-17T3 T2 T2 T2 T1 T1
18-23T4 T4 T4 T5 T6 T6
    
```

Each hour of the day can be associated with a specific energy threshold. The settings can be copied from one day to another, or for the entire week. Consequently, a different energy profile can be set for each individual day.

```

Exception setting C23
Insert exception
from 01 JANUARY
to 01 JANUARY
time band SPECIAL DAY
threshold ENERGY 1
ENTER ← to confirm
    
```

Exceptions are used to set the time period, type of day and energy profile for specific dates.

### 5.4 Exceptions to general scheduler

Up to 15 special periods can be set, representing exceptions to the general scheduler.

Screen for entering the exceptions.

```

Time band C04
No exceptions

Do you want to set the
exceptions?


Press ENTER
    
```

Select month using:



```


NOV 11 C05
M T W T F S S
07 08 09 10 11 12 13
14 15 16 17 18 19 20
21 22 23 24 25 26 27
28 29 30
    
```




Select day using:



Enter period the exception applies to. The same screen can be used to set the type of opening and the corresponding energy band.




The calendar shows where the exceptions have been entered.



**Note:** to cancel an exception, you need to: from this mask, press ENTER, press UP until you reach the highlighted exception that you want to delete, and then press ENTER. The exception will be deleted.





This screen shows the next exception and set any additional exceptions.



### 5.5 Scheduler setting for each load

The controller manages a scheduler for each load, with an offset for activating and deactivating the load in question (for details see paragraph 8.1 "Scheduler").



Enable the load for scheduling, set the on/off offset and the behaviour between bands.

**Note:** if a load is not managed by the scheduler, it is always ON even when the system is OFF.




## 5.6 Load cut-off configuration

The controller features settable three type of electrical load cut-off thresholds:

- energy threshold (kWh);
- power threshold (kW).
- apparent power threshold (kVA).


The effective load cut-off threshold is not the value set on the screens, but rather is adjusted by a settable offset, positive for power and apparent power, and negative for energy. To disable these offsets, simply set them to zero. For details on load cut-off operation, see paragraph 8.2 " Load cut-off".

The different thresholds can be loaded 'Automatically' or by 'Digital Input'; this depends on the type of the controller used: pLoads Large manages both options, 'Automatic' or 'Digital Input', while pLoads Compact only handles 'Automatic'. The digital inputs can only be used for selecting the Power and Apparent power thresholds. The different thresholds can be set on the following screens:




Both sizes of pLoads can enable load cut-off for the three measurements. Only on pLoads Large can 'DIN', Digital Input be selected to change in threshold.

### pLoads Large




If Digital Input is enabled for managing the change in threshold, these inputs only apply to the change in threshold for Power and Apparent power.

ID2 position	ID3 position	Threshold (parameter):
Closed	Closed	Row 1 (50 / 80)
Closed	Open	Row 2 (60 / 90)
Open	Closed	Row 3 (70 / 100)
Open	Open	Row 4 (80 / 110)




The Energy threshold is single and set on screen D05, where the monitoring time can also be set.






If 'automatic' management is enabled for changing the threshold, all three measurements are managed by the scheduler, and screen D05 only sets the energy monitoring time.

pLoads Compact




On pLoads Compact, the load cut-off thresholds are always managed by the scheduler and screen D05 only sets the energy monitoring time.

Below are the screens for setting the various load cut-off parameters:





The cut load delay is the same for all the loads; while the minimum and maximum cut time can be set for each single load, on loop (E.Load config).




Set the safety offsets for Power, Energy and Apparent Power load cut-off. For Power and Apparent Power the percentage is only positive, while for Energy the percentage is only negative.

For each load, you can enable the cutting loads and priority to activate it (for details, see "Loads cut-off" on par. 8.2).



Enable load cut-off and set the deactivation priority when load cut-off is required.



Each load, that is enabled for the cut load action, you can set the minimum and maximum time for cut.

## 6. INPUT/OUTPUT TABLE

Digital outputs	pLoads Large	pLoads Compact
NO1	Load 1	Alarm
NO2	Load 2	Load 1
NO3	Load 3	Load 2
NO4	Load 4	Load 3
NO5	Load 5	Load 4
NO6	Load 6	Load cut-off active
NO7	Load 7	
NO8	Load 8	
NO9	Load 9	
NO10	Load 10	
NO11	Load 11	
NO12	Load 12	
NO13	Alarm	
NO14	Load cut-off active	
NO15		
NO16		
NO17		
NO18		

Tab. 6.a

Digital inputs	pLoads Large	pLoads Compact
ID1	Remote ON/OFF - Alarm	Pulse counter
ID2	Rate band 1	Manual load control
ID3	Rate band 2	
ID4	Manual load 1	
ID5	Manual load 2	
ID6	Manual load 3	
ID7	Manual load 4	
ID8	Manual load 5	
ID9	Manual load 6	
ID10	Manual load 7	
ID11	Manual load 8	
ID12	Manual load 9	
ID13	Manual load 10	
ID14	Manual load 11	
ID15	Manual load 12	
ID16	Manual load control	
ID17	Pulse counter (with PCO208DI00)	
ID18	Pulse counter (with PCO208DI00)	

Tab. 6.b

Analogue outputs	pLoads Large	pLoads Compact
Y1		
Y2		
Y3		
Y4		
Y5		
Y6		

Tab. 6.c

Analogue inputs	pLoads Large	pLoads Compact
B1	Generic input 1, (V-I)	Generic input 1, (V-I)
B2	Generic input 2, (V-I)	Generic input 2, (V-I)
B3	Generic input 3, (V-I)	Generic input 3, (V-I)
B4		
B5	Pulse counter	Manual load 1
B6	Generic input 4, (V-I)	Manual load 2
B7	Generic input 5, (V-I)	Manual load 3
B8	Generic input 6, (V-I)	Manual load 4
B9		
B10		




Tab. 6.d




## 7. INSTALLER FUNCTIONS

### 7.1 Load installation

The controller features a digital input ('manual loads', see Tab. 6.b) used to notify the supervisor that one of the loads has been put in manual control, thus bypassing the controller logic. To enable this, the load and the manual switch will need to be connected, as shown in Fig. 7.h (par. 7.8). If there is no connection to the corresponding digital input, there will be no feedback that one of the loads has been switched on/off without being managed by the controller. For each load, a manual input is also available ('manual load X', see Tab. 6.b and 6.d) that, on variation, changes the load status until the next request. To set the logic parameters for the load outputs and inputs, access the following screens:



Set the number of loads controlled and the delay between different load activations so as to avoid peaks in power.




A label can be set for each load; this is then copied to all the screens that regard that specific load. The load output logic and manual control input (button) can also be set.

**Note:** the digital input reserved for 'Manual load X' will physically be a switch and not a button. pLoads will manage the transition of the switch OPEN→CLOSED and CLOSED→OPEN as a request to reverse load status at the moment the switch is operated. In this way, 'Manual load x' management bypasses the scheduler, load cut-off, etc.; for further details, see paragraph 8.4.

### 7.2 Pulse counter installation



The pulse generator device will have a free-contact digital output. In particular, pLoads Compact strictly requires a noise-free signal; a REED magnetic contact signal, due to its characteristics, is not classified as a free-contact signal and for this reason it's recommended a 'bounce' filter connected between the pulse generator device and ID1. The connections are shown in figure below:




#### Input signal characteristics

Type	Voltage-free contact
Typical current	5 mA
Maximum frequency	2 kHz

Fig. 7.a



Parameters can be set to adjust the weight of the pulse, reset, an offset count and, where necessary, to add pulses missed.



It is possible to modify the type of counter connected (energy, water, gas), enable a warning after a blackout to inform the user that the counter may have lost the pulse; so you can carry out a check.

The counters wireless CI have set it because it is equipped with a battery.

Type of controller	Max no. of pulse counter inputs	Remarks
pLoads Compact	5	1 built-in CI pulse counter (ID1) 2 wireless CI pulse counters (CI, add. 31) 2 wireless CI pulse counters (CI, add. 32)
pLoads Large	7	1 built-in CI pulse counter (B5) 2 built-in CI pulse counters (ID17-ID18) with PCO208DI00 device 2 wireless CI pulse counters (CI, add. 31) 2 wireless CI pulse counters (CI, add. 32)



**Important:** as shown in the table, pLoads Compact features just one built-in pulse counter input. pLoads Large, on the other hand, can manage two more (built-in): ID17 and ID18. They can be used as pulse counter inputs only if they interface with the CAREL PCO208DI00 device; it foresees one pulse output for every eight inputs, therefore count is performed by pLoads applying a factor of 8. For details on the operation of this device, see the specific documents, +05003570. Below is a connection diagram for the PCO208DI00 device to pLoads Large.




Fig. 7.b

### 7.3 Energy meter installation

The controller can manage up to 9 types of energy meter. pLoads can manage a maximum of 12 energy meters, and these must all be the same model. The following models can be selected on the user interface:

1. CAREL emeter3 (cod. Carel: MT300W1100);
2. Gavazzi CPT-DIN (basic);
3. Gavazzi WM14-DIN (basic);
4. Gavazzi WM14-96 (basic), si selezioni il modello 'Gavazzi CPT-DIN/WM14';
5. Ducati Energia Smart più;
6. IME Nemo 96 HD;
7. IME Nemo D4;
8. Electrex FEMTO D4;
9. Socomec (Diris A10).


The following screens are used to set the Modbus® communication parameters with the energy meter:



Set the communication speed with the devices, stop bits, parity control and timeout for offline alarm.



Set the number of energy meters on the Modbus® line and the type.





The main configuration parameters are displayed for each energy meter. In addition, the counters can be reset for the meters on the same screen. On the next mask, for CAREL emeter3 and Gavazzi (CPT-DIN, WM14-DIN and WM14-96) energy meters only, the device address can be set.


For connection details, see the following paragraph.

## 7.4 Supervisor installation

pLoads can be connected to various supervisory systems, in particular the following BMS communication protocols can be used: Carel RS485 and Modbus®. Both protocols are supported by PlantVisorPRO models, available from version SP 2.1.0 Connection is via a BMS serial port, already fitted for both models of pLoads. The supervisor communication settings are as follows.



Supervisor BMS port 1 setting: the supervisor protocol, baud rate and device serial address can be set. These settings must be the same as on the supervisor.



Supervisor BMS port 2 setting: only available on pLoads Large.

### pLoads Compact




Fig. 7.c



**Important:**

- on pLoads Compact, to connect the controller to a supervisor, fit card PCOS004850 (standard) in the "Serial card 1" slot.
- port J8 is connected to the energy meter as per the instructions.

pLoads Large




Fig. 7.d

Important:

- port J25 (BMS2) is connected to the Carel supervisor as the instructions.
- port J26 (FBus2) is connected to the energy meter as the instructions.

**Note:** on pLoads Large, serial BMS1 has been enabled where, using an optional supervisor card (not supplied as standard), pLoads can be connected to a second supervisory system. This is useful, for example, when wanting to install a pCOWeb card.




### 7.5 General settings

The controller can manage the installation of other devices, including:

1. Alarm relay;
2. Load cut-off in progress relay;
3. Remote ON-OFF/alarm input;
4. Current/Voltage reading inputs

For details on the operation of these devices, refer to chap. 8 'Operating logic' too.

The logic also needs to be configured for these devices, on the following screens:



Set the logic for "load cut-off active" and "alarm active" digital outputs.

```

General config. D08
By-passed loads
Input ID16
By-Pass=      IN OPENED

Remote ON-OFF
Input ID01
Building ON=  IN OPENED

```

Set the logic for "loads bypassed" and "remote ON-OFF" digital inputs.

```

Aux load D40
Number load/s reading
from AIN:      2

```

Depending on the model of pLoads, reading of some generic inputs can be enabled. This is used to read Current or Voltage values to measure the power consumption of a generic load when lower precision is possible. The following screens can then be used to set the type of sensor connected to the various inputs.

```

Aux load D47
Type load 1:  3-PHASES
P=U x I x cosfi x SQR3
I=            PROBE B1
U=            PROBE B2
Cosfi:        0.9
Reset:        NO

```

The auxiliary load can be monitored for Power and Energy. The Current reading is always the value measured by a sensor; the Voltage may be a parameter or the value read by a second sensor. The auxiliary load can be set as 'single-phase' or 'three-phase'. If 'three-phase', the Cos-fi value can be modified and will be considered when calculating the Power and Energy. The 'reset' function is used to reset the energy meter.

```

Aux load D47
Type load 1:  3-PHASES
P=U x I x cosfi x SQR3
I=            PROBE B1
U=            PARAMETER
Cosfi:        0.9
Fixed voltage: 380.00
Reset:        NO

```

'Three-phase' load with voltage value settable by parameter.

## 7.6 Wireless network installation

pLoads is perfectly integrated with the CAREL rTM wireless system. The energy meter can be connected to pLoads via a RB Router Bridge (see fig. 3.a). The network will therefore consist of an Access Point (with address 1) connected to the FieldBus serial port on the controller, and at least one RB Router Bridge with the corresponding energy meter connected via RS485; up to 2 CI pulse counters can also be used, with this configuration.

```

Access Point D32
Enable access point:
YES

```

Enabling the Access Point configures pLoads to accept data from a RB Router Bridge and CI pulse counter.

```

Access Point #01 D33
Type of access Point:
WITH ROUTER BRIDGE
Min address connected
to router bridge:    2
Max address connected
to router bridge:    5

```

Access point must be configured 'With Router Bridge' (see example). The "Min address" will be the lowest address of the Energy meter connected to RB Router Bridge; generally 2, which is the first useful for reading an energy meter in serial. The "Max address" will be the last serial address that pLoads will read and present on the network; usually the last address of the energy meter.

```
Pulse-Counter D34
Number of Pulse
counter(CI sensor): 1
```

Set the number of CI pulse counters to read, up to 2. The addresses must be 31 and 32.

```
Pulse-Counter D35
g31
Transmit data cycle: 0s
```

This screen can be used, only if the CI device is online, to modify the data transmission time. Remember that the lower the value, the shorter battery life will be.

The following screens, (D36, ...) are used to set the weight of the pulse for wireless devices, see paragraph 7.2. Remember that each CI pulse counter provides 2 fast inputs.

## 7.7 Description of the terminals

### pLoads Compact




Fig. 7.e

**Key:**

1	power supply connector (G, G0) 24 Vac or 48 Vdc (36 Vdc min to 72 Vdc max)
2	"SYNC" synchronicity inputs for phase control and 0 to 1 V, 0 to 5 V, 0 to 20 mA, 4 to 20 mA analogue inputs, +5 Vref to supply 5 V ratiometric probes and +VDC (+21 Vdc) for active probes
3	digital output
4	connector for all standard pCO series terminals and for downloading the application program
5	pLAN network connector
6	connector for pLD terminals
7	tLAN network connector
8	optically-isolated "Field-Bus" serial connector
9	0 to 10 V analogue and PWM phase control outputs (not used)
10	digital output
11	digital outputs
12	NTC analogue inputs and digital inputs
13	removable cover for USB access
14	digital outputs (type B)
15	digital outputs (type B)
16	Built-In terminal (LCD, buttons and LEDs)

Tab. 7.e



pLoadsLarge




Fig. 7.f

Key:

1.	power supply connector [G (+), G0 (-)]
2.	button and pLAN address, 7 segment display and LED (power on and +Vdc terminal overload)
3.	additional power supply for the terminal and 0 to 5 V ratiometric probes
4.	universal analogue inputs 0...1 V, 0...5 V ratiometric, 0...10V, 0...20 mA, 4...20 mA
5.	passive analogue inputs PT1000, ON/OFF
6.	0 to 10 V analogue outputs (not used)
7.	24 Vac/Vdc digital inputs
8.	230 Vac or 24 Vac/Vdc digital inputs
9.	display terminal connector (external panel with direct signals)
10.	connector for all standard pCO series terminals and for downloading the application program
11.	relay digital outputs
12.	Fieldbus2 connector
13.	pLAN network connector
14.	cover for inserting the supervisor serial card option (BMS1)
15.	cover for inserting the field card option (Fieldbus1)
16.	BMS2 connector
17.	Fieldbus2 connector
18.	Built-In terminal (LCD, buttons and LEDs)
19.	USB Host and Slave connector

Tab. 7.f

## 7.8 Electrical connections





Fig. 7.g



Load connection example:

The diagram shown below highlights the connection to the 'bypassed loads' input ID16 for pLoads LARGE:




Fig. 7.h

Counter connection example on pLoads Large:

- ID2, ID3: select energy band input
- B5: CI pulse counter input




Fig. 7.i

## 8. OPERATING LOGIC

### 8.1 Scheduler

Under Settings → Clock

As seen on par. 5.2, the scheduler can manage all the loads controlled by the scheduler; up to four types of time scheduling can be selected for each day of the week:

1. ORDINARY DAY
2. SPECIAL DAY
3. SHORT DAY
4. CLOSING DAY

For each type of time scheduling, an opening and closing time can be set in the morning and opening and closing time in the afternoon (except for Short Days, where only one daily band is managed). During the closing days no loads will be activated by the scheduler. The scheduler is only enabled when the system is ON.

Exceptions can be set to the daily scheduler. Up to 15 exception periods can be set, selecting the following options:

- first day/month of the exception;
- last day/month of the exception;
- type of day the controller will apply during the period;
- type of energy band exception (if from scheduler).



**Note:** exceptions are cyclical and therefore will be repeated every year until they are replaced or cancelled (see Note par. 5.4).

### Load scheduler

Under Settings → Load configuration, the behaviour of each individual load as regards the general scheduler can be set. The scheduler can be enabled or disabled and if enabled, before-opening, after-closing and behaviour of the load between morning and afternoon times can all be set.

Load before-opening and after-closing operation can be set with values ranging from 0 to 120 minutes.

During the scheduled time bands, three types of load operation can be selected:

1. BEFORE-AFTER BETWEEN TIME BANDS (the load will observe the after-closing and the pre-opening during the pause);
2. ALWAYS OFF BETWEEN TIME BANDS (the load will switch off immediately at the end of the load activation time band);
3. ALWAYS ON BETWEEN TIME BANDS (the load will remain on until deactivation is next requested by a time band).



**Note:** to disable a specific time band, set the same start and end times. This also allows an additional short day to be created. The before-opening and after-closing times are ignored if the time band is disabled.



**Note:** a before-opening operation that requires activation of the load on the previous day will be ignored. The load cannot be activated before midnight.



**Note:** an after-closing operation that requires deactivation of the load the following day will be applied.

**Example of load operation:**

Morning opening – closing times: 8:00 - 12:00

Afternoon opening – closing times: 14:00 - 18:30

	Before-opening	After-closing	Behaviour between bands
Load 1	30 minutes	60 minutes	BEFORE-AFTER between bands
Load 2	0 minutes	30 minutes	ON between time bands
Load 3	30 minutes	30 minutes	OFF between time bands




Fig. 8.a

**8.2 Load cut-off**

Load cut-off is only active when an energy meter is connected to the Field-Bus port on the controller. Power/energy control is not available with a pulse counter or the analogue inputs reserved for reading Current/Voltage (see par. 7.5). The energy meter must be connected as "general" in the system structure (see par. 7.3). With reference to paragraph 5.6, remember that pLoads deactivates loads based on the following measurements:

- Energy (kWh)
- Power (kW)
- Apparent Power (kVA)

Load cut-off times can be set, in particular:

- Delay between cutting off different loads (common for all);
- Minimum load cut-off time (for each load);
- Maximum load cut-off time (for each load).



**Note:** the delay between "cutting off different loads" applies to both deactivation and activation.



**Note:** rotation applied between the loads is LIFO (Last In First Out) and cannot be modified.

For each load, load cut-off can be enabled and the priority set. The load with the highest priority will be the first switched off when a load cut-off is required. Subsequently, if other loads need to be disconnected, the other loads will be cut off in order of lower priority. When the load cut-off request is no longer active, the controller will reactivate the loads again in order of priority.

```

Load 1 config. E03
Lights 1
Scheduler: YES
Preopening: 5min
Postclosing: 10min
PRE-POST BETWEEN BANDS
Cut load: YES
Switch-OFF for: 1
    
```

For each enabled load, the following settings are available:

- enable scheduler
- set a before-opening time
- set an after-closing time
- set behaviour between time bands
- enable load cut-off
- set the load cut-off priority

Below is an example of load cut-off:




Fig. 8.b

The graph shows how the loads switch off in order of priority, from the highest (load with priority 1) to the lowest (load with priority 3).

After the maximum load cut-off time, the load with priority 1 will switch on again even if the load cut-off request is still active.

Once the request is no longer active, the first load to switch on is the one with the lowest priority. The load with priority 2 will switch on without observing the delay between cutting off different loads as the maximum load cut-off time has elapsed.

### Load cut-off by Power and Apparent Power

Under Settings → General configuration, different power cut-off thresholds can be set (see paragraph 5.6).

The table below summarises the possible configurations:

Type of controller	Load cut-off by:	Threshold selection:
pLoads Compact	• Power (kW)	• AUTO (6 thresholds)
	• Energy (kWh)	
	• Apparent power (kVA)	
pLoads Large	• Power (kW)	• AUTO (6 thresholds)
	• Energy (kWh)	
	• Apparent power (kVA)	• DIN (4 thresholds for kW e kVA, 1 threshold for kWh)

On pLoads Large, load cut-off can be configured with the following settings:

- Digital input (4 thresholds for kW e kVA, 1 threshold for kWh)
- Automatic (6 possible thresholds)

2 digital inputs are available for selection with binary logic.

Below is an example of load cut-off by power:




Fig. 8.c

### Load cut-off by energy

Under 'Settings → General' configuration, the energy threshold and the monitoring time for energy can be set (see paragraph 5.6). The controller will record the energy values sent by the general meter according to the energy "monitoring time" parameter. If between the last energy value read and the energy value recorded over the previous minutes (determined by the energy monitoring time), energy consumption is higher than the energy threshold calculated, the load will be cut off. Below is an example of load cut-off by energy:




Fig. 8.d

### Load cut-off active function

The controller features the load cut-off active function (see the corresponding digital output in Tab. 6.a). When the controller is cutting off loads or the load cut-off conditions are true (so even when no load is enabled to be cut off), the "Load cut-off active" digital output will be activated. The system installer can connect this digital output to an input on an external power generator to signal greater demand.



**Note:** if the energy meter is offline, all types of load cut-off functions are disabled.



### 8.3 Override loads

#### Override from manual input

For each load connected to the controller, a digital input is available for enabling manual control by button. When the user operates the switch, load status will be reversed (if off it will be switched on, or if on it will be switched off). The load only temporarily reverses status, i.e. until the next ON/OFF request is received from the scheduler, supervisor, load cut-off or the digital input itself. The following pages describe how these different requests interact with one another.

#### Override from supervisor

For each load connected to the controller, a supervisor command is available for switching the load on or off.



Fig. 8.e

From the supervisor, each load can be switched MAN-ON, MAN-OFF or left in AUTO operation

- ➡ **Note:** if the supervisor is offline, the load will remain in the status set by the supervisor.
- ➡ **Note:** in the event of a power failure on pLoads, the command sent previously by the supervisor will be reset when the device starts again. To return the load to the previous status, the supervisor needs to send the command again.

### 8.4 Control interaction

After having analysed the different requests that affect a load, the interactions between these and the different priorities are illustrated below.




Fig. 8.f

Example of how the requests interact to determine load status:




Fig. 8.g


Key:

- 1 = load OFF;
- 2 = load ON by time zone;
- 3 = load OFF by manual mode;
- 4 = load OFF by cut-load;
- 5 = load ON by supervisor;
- 6 = load OFF by time zone;
- 7 = load OFF by cut-load;
- 8 = load ON by manual mode;
- 9 = load OFF by supervisor;
- 10 = load ON by time zone.

9. PARAMETERS TABLE

Below is the table of the parameters that can be displayed on the terminal. The values indicated with '---' are not significant or are not set, while the values indicated with '...' may vary according to the configuration, with the possible options visible on the user terminal. A row of '...' means that there are a series of parameters similar to the previous ones.

“Mask index”: indicates the unique address of each screen and consequently the path needed to reach the parameters available.

 **Note:** Not all the screens and parameters shown in the table are always visible or can be set, the screens and parameters that are visible or can be set depend on the configuration and the access level.

Mask index	Display descript.	Description	Def.	UoM	Values
<b>Main screen</b>					
Main screen for pLoads large (display only)	pLoads	The name of the product	---	---	---
	---	Hours ,minutes and date	---	---	---
	---	Weekday (Monday to Sunday)	---	---	---
	---	Weekday type (Full, Reduce, Special, Closing day)	---	---	---
	---	Energy	---	kWh/ MWh	0..9999999999
	---	Power	---	kW	0..9999
	Power percentage:	Power percentage:	---	%	0..999
	Energy percentage:	Energy percentage (can be selected)	---	%	0..999
	App.power perc.:	Apparent power percentage (can be selected)	---	%	0..999
	---	Unit status (with unit OFF)	---	---	Unit OFF by DIN Unit Off by keypad
	Load status	Read the status of loads	---	---	---
	---	Load 1 status (if enable)	---	---	0... 7 (see par. 2.1)
---	Load 2 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 3 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 4 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 5 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 6 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 7 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 8 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 9 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 10 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 11 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 12 status (if enable)	---	---	0... 7 (see par. 2.1)	
Main screen for pLoads compact (display only)	pLoads	The name of the product	---	---	---
	---	Hours ,minutes and date	---	---	---
	---	Weekday (Monday to Sunday)	---	---	---
	---	Weekday type (Full, Reduce, Special, Closing day)	---	---	---
	---	Energy	---	kWh/ MWh	0..9999999999
	---	Power	---	kW	0..9999
	Power percentage:	Power percentage	---	%	0..999
	Energy percentage:	Energy percentage (can be selected)	---	%	0..999
	App.power perc.:	Apparent power percentage (can be selected)	---	%	0..999
	---	Unit status (with unit OFF)	---	---	Unit OFF by DIN Unit Off by keypad
	Load status	Read the status of loads	---	---	...
	---	Load 1 status (if enable)	---	---	0... 7 (see par. 2.1)
---	Load 2 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 3 status (if enable)	---	---	0... 7 (see par. 2.1)	
---	Load 4 status (if enable)	---	---	0... 7 (see par. 2.1)	

Mask index	Display descript.	Description	Def.	UoM	Values
<b>A. General ON-OFF</b>					
A01	OFF by keyboard	Unit status	---	---	ON general / OFF from input / OFF from keyboard

Mask index	Display descript.	Description	Def.	UoM	Values
<b>E. Unit status</b> (the I/Os available depend on the selected configuration, the following are just some examples.)					
B01 (Read only)	Lights 1	The label of load 1	0	---	<b>See NOTE 1</b>
	---	Manual digital input (pLoads Large - ID4, pLoads Compact - B5)	---	---	0: Manual input ID4: 1: Manual input B5:
	---	Status of digital manual load 1	---	---	0: Close   1: Open
	---	Load output (pLoads Large - NO1, pLoads Compact - NO2)	---	---	0: Load output NO01: 1: Load output NO02:
B02 (Read only)	Conditioning 1	The label of load 2	7	---	<b>See NOTE 1</b>
	---	Manual digital input (pLoads Large - ID5, pLoads Compact - B6)	---	---	0: Manual input ID5: 1: Manual input B6:
	---	Status of digital manual load 2	---	---	0: Close   1: Open
	---	Load output (pLoads Large - NO2, pLoads Compact - NO3)	---	---	0: Load output NO02: 1: Load output NO03:
B03 (Read only)	LT Cabinet 1	The label of load 3	13	---	<b>See NOTE 1</b>
	---	Manual digital input (pLoads Large - ID6, pLoads Compact - B7)	---	---	0: Manual input ID6: 1: Manual input B7:
	---	Status of digital manual load 3	---	---	0: Close   1: Open
	---	Load output (pLoads Large - NO3, pLoads Compact - NO4)	---	---	0: Load output NO03: 1: Load output NO04:
B04 (Read only)	NT Cabinet 1	The label of load 4	16	---	<b>See NOTE 1</b>
	---	Manual digital input (pLoads Large - ID7, pLoads Compact - B8)	---	---	0: Manual input ID7: 1: Manual input B8:
	---	Status of digital manual load 4	---	---	0: Close   1: Open
	---	Load output (pLoads Large - NO4, pLoads Compact - NO5)	---	---	0: Load output NO04: 1: Load output NO05:
...	...	...	...	...	<b>See NOTE 2</b>
B13 (Only pLoads Large can read)	Remote ON-OFF ID01:	Status of digital input remote ON-OFF	---	---	0: Close   1: Open
	Band1 input ID02:	IN 1 for band of energy/power/apparent power	---	---	0: Close   1: Open
	Band2 input ID03:	IN 2 for band of energy/power/apparent power	---	---	0: Close   1: Open
B14 (Read only)	---	pLoads bypassed (pLoads Large - ID16, pLoads Compact - ID2)	---	---	0: pLoads bypassed ID02: 1: pLoads bypassed ID16:
	---	Status of digital input load by-passed	---	---	0: Close 1: Open
B15 (Read only)	---	Status of digital input load by-passed	---	---	0: Alarm NO1: 1: Alarm NO13:
	---	Alarm output (pLoads Large - NO13, pLoads Compact - NO1)	---	---	0: Close 1: Open
	---	General alarm status	---	---	0: Cut active NO6: 1: Cut active NO14:
	---	Cut active output (pLoads Large - NO14, pLoads Compact - NO6)	---	---	0: Close 1: Open
B16 (Read only, if enable)	Power(kW):	Power	---	---	0... 32767
	Energy(kWh):	Energy	---	---	0...32767
	Apparent p.(kVA):	Apparent power	---	---	0...32767
	Power percentage:	Power percentage	---	%	0...999
	Energy percentage:	Energy percentage	---	%	0...999
	App.power perc.:	Apparent power percentage	---	%	0...999
B17 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---	<b>See NOTE 3</b>
	---	Energy meter 1 address	---	---	2... 13
	Voltages (V) L1-L2:	Energy meter 1, Voltage L1-L2	---	V	0... 9999
	L2-L3:	Energy meter 1, Voltage L2-L3	---	V	0... 9999
	L3-L1:	Energy meter 1, Voltage L3-L1	---	V	0... 9999
	Average:	Energy meter 1, Phase-phase average voltage	---	V	0... 9999
	Total:	Energy meter 1, Voltage total average	---	V	0... 9999
	Frequency (Hz):	Energy meter 1, Frequency	---	Hz	0... 999.9
B18 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---	<b>See NOTE 3</b>
	---	Energy meter 1 address	---	---	2... 13
	Voltages (V) Neutral 1:	Energy meter 1, Voltage L1	---	V	0... 9999
	Neutral 2:	Energy meter 1, Voltage L2	---	V	0... 9999
	Neutral 3:	Energy meter 1, Voltage L3	---	V	0... 9999
	Total:	Total (only can be show with CAREL Emeter3)	---	V	0...9999

Mask index	Display descript.	Description	Def.	UoM	Values
B19 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---	See NOTE 3
	---	Energy meter 1 address	---	---	2... 13
	Current (A) Line 1:	Energy meter 1 (Building consumption), Current line 1	---	A	0... 999.9
	Line 2:	Energy meter 1 (Building consumption), Current line 2	---	A	0... 999.9
	Line 3:	Energy meter 1 (Building consumption), Current line 3	---	A	0... 999.9
	Power factor:	Power factor part 1	---	---	0... 9
		Power factor part 2	---	---	0... 99
	L1	Power factor L1 part 1 (only can be show CAREL Emeter3)	---	---	0... 9
		Power factor L1 part 2 (only can be show CAREL Emeter3)	---	---	0... 99
	L2	Power factor L2 part 1 (only can be show CAREL Emeter3)	---	---	0... 9
		Power factor L2 part 2 (only can be show CAREL Emeter3)	---	---	0... 99
	L3	Power factor L3 part 1 (only can be show CAREL Emeter3)	---	---	0... 9
		Power factor L3 part 2 (only can be show CAREL Emeter3)	---	---	0... 99
	B20 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---
---		Energy meter 1 address	---	---	2... 13
Apparent power (kVA) Phase 1:		Apparent power of phase 1	---	kVA	0.0..999.9
Phase 2:		Apparent power of phase 2	---	kVA	0.0..999.9
Phase 3:		Apparent power of phase 2	---	kVA	0.0..999.9
Total:	Total apparent power	---	kVA	0.0..999.9	
B21 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---	See NOTE 3
	---	Energy meter 1 address	---	---	2... 13
	Reactive power (kVar) Phase 1:	Reactive power 1	---	kVar	0... 999.9
	Phase 2:	Reactive power 2	---	kVar	0... 999.9
	Phase 3:	Reactive power 3	---	kVar	0... 999.9
	Total:	Total reactive power	---	kVar	0... 999.9
	Reactive energy eq.:	Reactive energy high part	---	---	0... 9999
		Reactive energy middle part	---	---	0... 999
Reactive energy low part		---	---	0... 999	
---	Reactive energy meter is reading in MWh	---	---	0: kVarh  1: MVarh	
B22 (Read only, if enable)	CAREL emeter3	Energy meter 1 type	---	---	
	---	Energy meter 1 address	---	---	2... 13
	Power (kW) Phase 1:	Power 1	---	kW	0... 999.9
	Phase 2:	Power 2	---	kW	0... 999.9
	Phase 3:	Power 3	---	kW	0... 999.9
	Total:	Energy meter 1 (Building consump.), Equivalent power	---	kW	0... 999.9
	Energy:	Energy value high part	---	---	kWh 0... 9999
		Energy value middle part	---	---	kWh 0... 999
		Energy value low part	---	---	kWh 0... 999
	---	Energy meter is reading in MWh	---	---	0: kWh  1: MWh
B23 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2 address	---	---	2... 13
	Voltagess (V) L1-L2:	Energy meter 2, Voltage L1-L2	---	V	0... 9999
	L2-L3:	Energy meter 2, Voltage L2-L3	---	V	0... 9999
	L3-L1:	Energy meter 2, Voltage L3-L1	---	V	0... 9999
	Average:	Energy meter 2, Phase-phase average voltage	---	V	0... 9999
Frequency (Hz):	Energy meter 2, Frequency	---	Hz	0... 999.9	
B24 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2 address	---	---	2... 13
	Tensioni (V) Neutr0 1:	Energy meter 2, Voltage L1	---	V	0... 9999
	Neutro 2:	Energy meter 2, Tensione L2	---	V	0... 9999
	Neutro 3:	Energy meter 2, Tensione L3	---	V	0... 9999
---	Total (only can be show with CAREL Emeter3)	---	V	0... 9999	
B25 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2 address	---	---	2... 13
	Current (A) Line 1:	Energy meter 2, Current line 1	---	A	0... 999.9
	Line 2:	Energy meter 2, Current line 2	---	A	0... 999.9
	Line 3:	Energy meter 2, Current line 3	---	A	0... 999.9
	Power factor:	Power factor part 1	---	---	0... 9
		Power factor part 2	---	---	0... 99
	L1	Power factor L1 part 1 (only can be shown with Carel Emeter3)	---	---	0... 9
		Power factor L1 part2 (only can be shown with Carel Emeter3)	---	---	0... 99
	L2	Power factor L2 part1 (only can be shown with Carel Emeter3)	---	---	0... 9
		Power factor L2 part2 (only can be shown with Carel Emeter3)	---	---	0... 99
	L3	Power factor L3 part 1 (only can be shown with Carel Emeter3)	---	---	0... 9
		Power factor L3 part 2 (only can be shown with Carel Emeter3)	---	---	0... 99

Mask index	Display descript.	Description	Def.	UoM	Values
B26 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2, (modbus address 3)	---	---	2... 13
	Apparent power (kVA) Phase 1:	Apparent power of phase 1	---	kVA	0.0..999.9
	Phase 2:	Apparent power of phase 2	---	kVA	0.0..999.9
	Phase 3:	Apparent power of phase 2	---	kVA	0.0..999.9
	Total:	Total apparent power	---	kVA	0.0..999.9
B27 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2, (address modbus 3)	---	---	2... 13
	Reactive power (kVAr) Phase 1:	Reactive power 1	---	kVAr	0... 999.9
	Phase 2:	Reactive power 2	---	kVAr	0... 999.9
	Phase 3:	Reactive power 3	---	kVAr	0... 999.9
	Total:	Total apparent power	---	kVA	0.0..999.9
	Reactive energy eq.:	Reactive energy high part	---	---	0... 9999
	---	Reactive energy middle part	---	---	0... 999
	---	Reactive energy low part	---	---	0... 999
	---	Reactive energy meter is reading in kVArh/MVArh	---	---	0: kVArh  1: MVArh
B28 (Read only, if enable)	CAREL emeter3	Energy meter 2 type	---	---	See NOTE 3
	---	Energy meter 2, (address modbus 3)	---	---	2... 13
	Power (kW) Phase 1:	Power 1	---	kW	0... 999.9
	Phase 2:	Power 2	---	kW	0... 999.9
	Phase 3:	Power 3	---	kW	0... 999.9
	Total:	Energy meter 2 (Building consumption), Equivalent power	---	kW	0... 999.9
	Energy:	Energy value high part	---	kWh	0... 9999
	---	Energy value middle part	---	kWh	0... 999
	---	Energy value low part	---	kWh	0... 999
	---	Energy meter is reading in MWh	---	---	0: kWh  1: MWh
B89 (Read only)	---	Pulse counter from (pLoads Large – ID1, pLoads Compact – B5)	---	---	0: Counter from ID1 1: Counter from B5
	Totale:	Totally pulse counter digital 0	---	---	0... 9
		Totally pulse counter digital 1	---	---	0... 9
		Totally pulse counter digital 2	---	---	0... 9
		Totally pulse counter digital 3	---	---	0... 9
		Totally pulse counter digital 4	---	---	0... 9
		Totally pulse counter digital 5	---	---	0... 9
		Totally pulse counter digital 6	---	---	0... 9
		Totally pulse counter digital 7	---	---	0... 9
		Totally pulse counter digital 8	---	---	0... 9
		Totally pulse counter digital 9	---	---	0... 9
		Totally pulse counter digital 10	---	---	0... 9
		Totally pulse counter digital 11	---	---	0... 9
		Totally pulse counter digital 12	---	---	0... 9
		Totally pulse counter digital 13	---	---	0... 9
		Totally pulse counter digital 14	---	---	0... 9
		Totally pulse counter digital 15	---	---	0... 9
---	Tipo dispos. da leggere (0: Energia; 1: Acqua; 2: Gas)	---	---	0: Wh 1: l 2: m <sup>3</sup>	
Frequency:	Frequency of the pulse counter	---	Hz	0... 16384	
B92 (Read only, if enable)	1-phase load with	Phase type load 1	---	---	0: (1-phase load with 1: (3-phases load with
	fix voltage value		---	---	0: AIN voltage value) 1: fix voltage value)
	Voltage:	Voltage load 1	---	V	0... 999.0
	Current:	Current load 1	---	A	0... 999.9
	Power:	Power load 1	---	kW	0... 999.9
Energy:	Energy medium part	---	kWh	0... 999	
	Energy low part	---	kWh	0... 999	
B93 (Read only, if enable)	1-phase load with	Phase type load 2	---	---	0: (1-phase load with 1: (3-phases load with
	fix voltage value		---	---	0: AIN voltage value) 1: fix voltage value)
	Voltage:	Voltage load 2	---	V	0... 999.0
Current:	Current load 2	---	A	0... 999.9	

Mask index	Display descrpt.	Description	Def.	UoM	Values
	Power:	Power load 2	---	kW	0...999.9
	Energy:	Energy medium part	---	kWh	0...999
		Energy low part	---	kWh	0...999
B102 (Read only, if enable wireless sensor)	Press Enter to see the wireless information	---	---	---	---
B103 (Read only)	Access point	Address of access point	1	---	1
	Firmware version:	Firmware version of access point	---	---	
	AP Trasmi.power:	Transmit power of access point	---	---	
	Radio signal lev.:	Signal level	---	---	
B104 (Read only)	Access point	Address of access point	1	---	1
	Num. of connected units (online units)	Connected units with access point online	---	---	0...112
	No. of units connected access point:	Connected units with access point	---	---	0...32
	No. of units connected through RB-device:	Number of units connected with Router Bridge RB	---	---	0...255
B105 (Read only)	Access point	Address of access point	1	---	1
	No. of router network:	Number of Router Bridge RB in the netwrok	---	---	0...32767
	No. of router nearby:	Number of router nearby	---	---	0...16
	No. of router nearby with good connect.:	Number of router nearby with good connection	---	---	0...16
B106 (Read only)	Cl device	Address of pulse counter	31	---	31...32
	Firmware version:	Firmware version of pulse counter	---	---	
	Radio signal:	Radio signal with access point	---	---	1...4
	Battery level:	Battery level of pulse counter	---	---	1...4

Mask index	Display descrpt.	Description	Def.	UoM	Values
<b>C. Clock</b>					
C01	Day:	Weekday (Monday to Sunday)	---	---	0:*** 4:Thursday 1: Monday 5: Friday 2: Tuesday 6: Saturday 3: Wednesday 7: Sunday
	Date format:	Date format showing on the main mask	1	---	1: DD/MM/YY 2: MM/DD/YY 3: YY.MM.DD
	Date format:	Set the new date - day	---	---	0...31
		Set the new date - month	---	---	0...12
		Set the new date - year	---	---	0...99
	Set the new date - day	Set the new time - hour	---	---	0...23
		Set the new time - minute	---	---	0...59
C02	DST:	Activates the module algorithm	1	---	0: Disable 1: Enable
	Start:	Set DST week change	0	---	0: Last 3: Third 1: First 4: Fourth 2: Second
		Set day start DST	0	---	0:*** 4:Thursday 1: Monday 5: Friday 2: Tuesday 6: Saturday 3: Wednesday 7: Sunday
	in	Set month start DST	0	---	0:*** 7: July 1: January 8: August 2: February 9: Septem 3: March 10: October 4: April 11: Novemb 5: May 12: Decemb. 6: June
		Set hour start DST	0	---	0...23
	End:	Set day stop DST	0	---	0: Last 3: Third 1: First 4: Fourth 2: Second
		Set month stop DST	0	---	0:*** 4:Thursday 1: Monday 5: Friday 2: Tuesday 6: Saturday 3: Wednesday 7: Sunday

Mask index	Display descript.	Description	Def.	UoM	Values
	In	Set hour stop DST	0	---	0: *** 1: January 2: February 3: March 4: April 5: May 6: June 7: July 8: August 9: Septem 10: October 11: Novem.b. 12: Decemb.
		Set DST stop	0	---	0...23
C03	Full day	Starting of Time Band 1, full day 1	8	H	0...23
		Starting of Time Band 1, full day 1	0	M	0...59
		Ending of Time Band 1, full day 1	13	H	0...23
		Ending of Time Band 1, full day 1	0	M	0...59
		Starting of Time Band 2, full day 1	14	H	0...23
		Starting of Time Band 2, full day 1	0	M	0...59
	Special day	Ending of Time Band 2, full day 1	18	H	0...23
		Ending of Time Band 2, full day 1	0	M	0...59
		Starting of Time Band 1, full day 2	9	H	0...23
		Starting of Time Band 1, full day 2	0	M	0...59
		Ending of Time Band 1, full day 2	13	H	0...23
		Ending of Time Band 1, full day 2	0	M	0...59
	Reduce day	Starting of Time Band 2, full day 2	14	H	0...23
		Starting of Time Band 2, full day 2	0	M	0...59
		Ending of Time Band 2, full day 2	16	H	0...23
		Ending of Time Band 2, full day 2	0	M	0...59
		Starting, reduce day 1	9	H	0...23
		Starting, reduce day 1	0	M	0...59
		Ending reduced day 1	17	H	0...23
		Ending reduced day 1	0	M	0...59
C04	Monday:	Type scheduler Monday	0	---	0...3
	Tuesday:	Type scheduler Tuesday	0	---	0...3
	Wednesday:	Type scheduler Wednesday	1	---	0...3
	Thursday:	Type scheduler Thursday	0	---	0...3
	Friday:	Type scheduler Friday	0	---	0...3
	Saturday:	Type scheduler Saturday	2	---	0...3
	Sunday:	Type scheduler Sunday	3	---	0...3
C05(if enable)	Day:	Set the day	0	---	1: Monday 2: Tuesday 3: Wednesday 4: Thursday 5: Friday 6: Saturday 7: ---
	Copy to:	Set the copy day	0	---	0: Monday 1: Tuesday 2: Wednesday 3: Thursday 4: Friday 5: Saturday 6: Sunday 7: All
	00-05	Set the threshold for each hour (00, 01, 02, 03, 04, 05)	0	---	0: T1 1: T2 2: T3 3: T4 4: T5 5: T6
	06-11	Set the threshold for each hour (06, 07, 08, 09, 10, 11)	0	---	0: T1 1: T2 2: T3 3: T4 4: T5 5: T6
	12-17	Set the threshold for each hour (12, 13, 14, 15, 16, 17)	0	---	0: T1 1: T2 2: T3 3: T4 4: T5 5: T6
	18-23	Set the threshold for each hour (18, 19, 20, 21, 22, 23)	0	---	0: T1 1: T2 2: T3 3: T4 4: T5 5: T6
C06 (if enable)	Exception:	Set exception threshold	0	---	0: ENERGY 1 1: ENERGY 2 2: ENERGY 3 3: ENERGY 4 4: ---
	Copy to:	Set exception threshold	0	---	0: ENERGY 1 1: ENERGY 2 2: ENERGY 3 3: ENERGY 4 4: ALL
	00-05	Set the threshold for each hour (00, 01, 02, 03, 04, 05)	0	---	0: T1 1: T2 2: T3 3: T4 4: T5 5: T6



Mask index	Display descrpt.	Description	Def.	UoM	Values
	06-11	Set the threshold for each hour (06, 07, 08, 09, 10, 11)	0	---	0: T1 3: T4 1: T2 4: T5 2: T3 5: T6
	12-17	Set the threshold for each hour (12, 13, 14, 15, 16, 17)	0	---	0: T1 3: T4 1: T2 4: T5 2: T3 5: T6
	18-23	Set the threshold for each hour (18, 19, 20, 21, 22, 23)	0	---	0: T1 3: T4 1: T2 4: T5 2: T3 5: T6
C07 (if enable, read only)	Reception 01/ From	Show the exceptions number Start exception day	---	---	0...15 1...31
		Strat exception month	---	---	1...12
	to	Stop exception day	---	---	1...31
		Stop exception month	---	---	1...12
	Time band:	Set day type	0	---	0...3
	Threshold:	Set threshold type	0	---	0...3
---	---	---	---	---	---
C22	Next exception	---	---	---	0: No exceptions 1: Next exception
	---	Next event present day and month	---	---	0...31 0...12
	---	Type of period for next exception	---	---	0...3
	---	Type of threshold for next exception	---	---	0...3
C23 (if enable set exception)	---	Set month	0	---	1...12
	---	Read year	---	---	0...99
	---	Set start day	---	---	0: Do not set  1: Set
	---	Set end day	---	---	0: Do not set  1: Set
	---	Set period finish	---	---	0: --  1: END PERIODS!!
C23	Inset exception from	Set start day	---	---	0...31
		Set start month	---	---	0...12
	to	Set end day	---	---	0...31
		Set end month	---	---	0...12
	time band	Type of special period	0	---	0: FULL DAY 1: SPECIAL DAY 2: REDUCE DAY 3: CLOSING DAY
	threshold	Type of threshold	0	---	0: ENERGY 1 1: ENERGY 2 2: ENERGY 3 3: ENERGY 4
	---	Enter to confirm	---	---	---

Mask index	Display descrpt.	Description	Def.	UoM	Values
<b>D. General config.</b> (The I/Os available depend on the selected configuration, the following are just some examples)					
D01 (if enable)	Enable cut-load by: Power(kW):	Enable cut load by power	---	---	0: NO  1: YES
	Energy(kWh):	Enable cut load by energy	---	---	0: NO  1: YES
	Apparent pow.(kVA):	Enable cut load by apparent power	---	---	0: NO  1: YES
	Set threshold	Set threshold type	0	---	0: DIN  1: AUTO
D02	Percentage field on main mask:	Select which percentage showing on the main mask	0	---	0: POWER 1: ENERGY 2: APPARENT POWER
D03 (Only for pLoads Large and enable)	Power cut Threshold (kW) (kVA) ID2 ID3	Thresholds of power and apparent power for cut load by ID2 and ID3	0	kW	0...32767
	X X	Threshold 1 of power and apparent power for start the cut	0	kW	0...32767
	X O	Threshold 2 of power and apparent power for start the cut	0	kW	0...32767
	O X	Threshold 3 of power and apparent power for start the cut	0	kW	0...32767
	OO	Threshold 4 of power and apparent power for start the cut	0	kW	0...32767

Mask index	Display descrpt.	Description	Def.	UoM	Values
D04(if enable)	kW kWh kVA T1:	Set threshold for T1	50	kW	0...32767
		Set threshold for T1	100	kWh	0...32767
		Set threshold for T1	80	kVA	0...32767
	kW kWh kVA T2:	Set threshold for T2	60	kW	0...32767
		Set threshold for T2	110	kWh	0...32767
		Set threshold for T2	90	kVA	0...32767
	kW kWh kVA T3:	Set threshold for T3	70	kW	0...32767
		Set threshold for T3	120	kWh	0...32767
		Set threshold for T3	100	kVA	0...32767
	kW kWh kVA T4:	Set threshold for T4	80	kW	0...32767
		Set threshold for T4	130	kWh	0...32767
		Set threshold for T4	110	kVA	0...32767
	kW kWh kVA T5:	Set threshold for T5	90	kW	0...32767
		Set threshold for T5	140	kWh	0...32767
		Set threshold for T5	120	kVA	0...32767
	kW kWh kVA T6:	Set threshold for T6	100	kW	0...32767
Set threshold for T6		150	kWh	0...32767	
Set threshold for T6		130	kVA	0...32767	
D05 (if enable)	Energy cut Threshold:	Threshold to cut the loads for energy	0	kWh	0...32767
	Time check:	Time to check the energy	15	min	1...60
D06 (if enable)	Safety to cut based on power:	Percentage to cut loads for power	30	%	1...100
		Percentage to cut loads for energy	30	%	1...100
		Percentage to cut loads for apparent power	30	%	1...100
D07 (if enable)	Delay between diff. cuts:	Delay between different cut	60	s	0...9999
D08	By-passed loads	Input channel (pLoads Large – Input ID16, pLoads Compact – Input ID12)	---	---	0: Input ID16 1: Input ID02
	By-pass=	Logic for digital input of load by-passed	0	---	0: IN OPENED 1: IN CLOSED
	---	Remote on-off DIN (pLoads large)	---	---	0: 1: Remote ON-OFF
	---	Input ID01 (pLoads large)			0: 1: Input ID01
	---	Building on logic (pLoads large)	0	---	0: IN OPENED 1: IN CLOSED
D09	Alarm active	Output channel (pLoads Large : Output NO13, pLoads Compact : Output NO1)	---	---	0: Output NO1: 1: Output NO13:
	Output ON=	Logica uscita digitale per segnalazione allarme	0	---	0: RELAY CLOSED 1: RELAY OPENED
	Cut active	Output channel (pLoads Large – Output NO14, pLoads Compact – Output NO6)	---	---	0: Output NO6: 1: Output NO14:
	Output ON=	Logic for relay cut active (0: Normally open; 1: Normally closed)	0	---	0: RELAY CLOSED 1: RELAY OPENED
D10 (if enable)	Number of energy meter connected on FBus:	Number of energy meter in modBus	0	---	0...12
	Type of energy meter:	Type of energy meter (0: IME HD; 1: IME D4; 2: Ducati; 3: Gavazzi; 4: Socomec; 5: Electrex; 6: CAREL emeter3)	6	---	0: IME NEMO 96 HD 1: IME NEMO D4 2: DUCATI ENERGIA SMART + 3: GAVAZZI CPT/WM14-DIN 4: SOCOMEC 5: ELECTREX FEMTO 6: CAREL emeter3

Mask index	Display descript.	Description	Def.	UoM	Values
D13 (if enable)	CAREL emeter3	Emery meter 1 type	---	---	0: IME Nemo 96HD 1: IME Nemo D4 2: Ducati Smart 3: Gavazzi 4: Socomec 5: Electrex 6: CAREL emeter3
---	---	Energy meter 1 address	---	---	2... 13
---	New address:	New address	1	---	2...13
---	System type:	System type	---	---	0..4
---	Primary CT:	CT value high part	---	---	0..999
---	---	CT value low part	---	---	0..999
---	---	Secondary CT	---	---	0..5
---	Primary VT:	VT value high part	---	---	0..999
---	---	VT value low part	---	---	0..999
---	---	Secondary VT	---	---	0..999
---	Reset counters:	Reset the counter	0	---	0: NO  1: YES
---	---	---	---	---	---
D25	---	Pulse counter from (pLoads Large – ID1, pLoads Compact – B5)	---	---	0: Counter from ID1 1: Counter from B5
---	Type of device	Type device (0: Energy; 1: Water; 2: Gas)	---	---	0: Wh;  2: m <sup>3</sup> 1: l
---	Pulse weight:	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>^</sup> Pulse_Conversion	0	---	0: 1  4: 10000 1: 10  5: 100000 2: 100  6: 0,1 3: 1000
---	Blackout warning:	Enable blackout warning	0	---	0: NO  1: YES
D26	---	Pulse counter from (pLoads Large – ID1, pLoads Compact – B5)	---	---	0: Counter from ID1 1: Counter from B5
---	Pulse lost for	Type device (0: Energy; 1: Water; 2: Gas)	---	---	0: Wh;  2: m <sup>3</sup> 1: l
---	---	New offset for the meter (Value x pulse weight)	0	---	0..999
---	Confirm?	New value for pulse counter	0	---	0: NO  1: YES
---	Reset meter?	Reset the counter	0	---	0: NO  1: YES
---	---	Totally pulse counter digital 0	---	---	0..9
---	---	Totally pulse counter digital 1	---	---	0..9
---	---	Totally pulse counter digital 2	---	---	0..9
---	---	Totally pulse counter digital 3	---	---	0..9
---	---	Totally pulse counter digital 4	---	---	0..9
---	---	Totally pulse counter digital 5	---	---	0..9
---	---	Totally pulse counter digital 6	---	---	0..9
---	---	Totally pulse counter digital 7	---	---	0..9
---	---	Totally pulse counter digital 8	---	---	0..9
---	---	Totally pulse counter digital 9	---	---	0..9
---	---	Totally pulse counter digital 10	---	---	0..9
---	---	Totally pulse counter digital 11	---	---	0..9
---	---	Totally pulse counter digital 12	---	---	0..9
---	---	Totally pulse counter digital 13	---	---	0..9
---	---	Totally pulse counter digital 14	---	---	0..9
---	---	Totally pulse counter digital 15	---	---	0..9
---	---	Type device (0: Energy; 1: Water; 2: Gas)	---	---	0: Wh;  2: m <sup>3</sup> 1: l
---	---	---	---	---	---
D32	Enable access point:	Enable access point	---	---	0: NO  1: YES

Mask index	Display descript.	Description	Def.	UoM	Values
D33 (if enable)	Access point	Address of access point	---	---	1
	Type of access point:	Type of access point	0	---	21: WITHOUT ROUTER-BRIDGE 17: WITH ROUTER-BRIDGE
	Min address connected to Router Bridge RB:	Min address connected to Router Bridge RB	0	---	2...13
	Max address connected to Router Bridge RB:	Max address connected to Router Bridge RB:	0	---	2...13
D34 (if enable)	Number of pulse counter(CI sensor):	Number of wireless CI pulse counter	0	---	0..2
D35	Pulse counter	Address of CI wireless pulse counter 1	---	---	31...32
	Transmit data cycle:	Transmission data cycle time	60	s	5...3600
	---	Address of CI wireless pulse counter 2	---	---	31...32
D36	---	Transmit data cycle time	60	s	5...3600
	Counter from CI01-ID1 Type of device:	Type device (0: Energy; 1: Water; 2: Gas)	---	---	0: Wh; 1: l 2: m <sup>3</sup>
	Pulse weight:	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>^</sup> Pulse_Conversion	0	---	0: 1 1: 10 2: 100 3: 1000 4: 10000 5: 100000 6: 0,1
	---	Totally pulse counter digital 0	---	---	0...9
	---	Totally pulse counter digital 1	---	---	0...9
	---	Totally pulse counter digital 2	---	---	0...9
	---	Totally pulse counter digital 3	---	---	0...9
	---	Totally pulse counter digital 4	---	---	0...9
	---	Totally pulse counter digital 5	---	---	0...9
	---	Totally pulse counter digital 6	---	---	0...9
	---	Totally pulse counter digital 7	---	---	0...9
	---	Totally pulse counter digital 8	---	---	0...9
	---	Totally pulse counter digital 9	---	---	0...9
	---	Totally pulse counter digital 10	---	---	0...9
	---	Totally pulse counter digital 11	---	---	0...9
	---	Totally pulse counter digital 12	---	---	0...9
	---	Totally pulse counter digital 13	---	---	0...9
---	Totally pulse counter digital 14	---	---	0...9	
---	Totally pulse counter digital 15	---	---	0...9	
---	Type device (0: Energy; 1: Water; 2: Gas)	---	---	0: Wh; 1: l 2: m <sup>3</sup>	
---	---	---	---	---	
D40	Number load/s reading from AIN:	Number of load reading from AIN	0	---	0...(pLoads Large: 6 – pLoads Compact: 4)
D41	Analog input Bxx	Specify the analogue input channel	---	---	1...20
	Configuration Probe type:	Specify the probe type	0	---	0: NTC 7: 0-5V 1: PT1000 8: 0.5-4.5V 2: 0-1V 9: NTC HT 3: 0-10V 10: -50T90 4: 0-20mA 11: 10T170 5: 4-20mA 12: PT100 6: ON/OFF
	Min value:	Conversion limit min value for the controlled value for active inputs	0	---	-3276.8...3276.7
	Max value:	Conversion limit max value for the controlled value for active inputs	1000	---	-3276.8...3276.7
	Alarm delay: Offset:	Specify the alarm delay time Offset of the probe value	60 0	s ---	0...32000 -3276.8...3276.7
---	---	---	---	---	

Mask index	Display descrpt.	Description	Def.	UoM	Values
D47	Type load 1:	Phase type load 1 (0: mono-phase; 1: three-phase)	0	---	0: 1-PHASE 1: 3-PHASES
	---	Power formula	---	---	0: P=V x I 1: P=V x I x cosfi x SQR3
	I=	Probe position number: current load 1	0	---	0: - 1: PROBE B1 2: PROBE B2 3: PROBE B3 4: PROBE B6 5: PROBE B7 6: PROBE B8 7: PARAMETER
	V=	Probe position number: voltage load 1	0	---	0: PARAMETER 1: PROBE B1 2: PROBE B2 3: PROBE B3 4: PROBE B6 5: PROBE B7 6: PROBE B8
	---	Fixed Cosfi load 1	0.0	---	0.0...1.0
	---	Fixed voltage load 1	0.0	V	0.0...999.9
	Reset:	Reset energy load 1	0	---	0: NO  1: YES
...	...	...	...	...	...
D53	DEFAULT INSTALLATION Delete user parameters and install global default:	Manual Inatallation of device default values (0: No default, 1: Default)	0	---	0: NO  1: YES
	---	Manual Initialisation of device default values (0: No default, 1: Default)	0	---	0:  1: Please wait...

Mask index	Display descrpt.	Description	Def.	UoM	Values
<b>E.Load config.</b> (The I/Os available depend on the selected configuration, the following are just some examples)					
E01	Load number:	Loads number	4	---	pLoads Large: 0...12 pLoads Compact: 0...4
	Delay between ON of different loads:	Delay between ON of different loads	5	s	0...180
E02	Label:	Label of load 1	0	---	<b>See NOTE 1</b>
	---	Load output channel (pLoads Large – NO1, pLoads Compact – NO2)	---	---	0: Load output NO01 1: Load output NO02
	Load ON=	Logic for relay load 1 (0: Normally open; 1: Normally closed)	0	---	0: RELAY CLOSED 1: RELAY OPENED
---	Manual input channel (pLoads Large – ID4, pLoads Compact – B5)	---	---	0: Manual input ID4 1: Manual input B5	
E03	Lights 1	Label of load 1	---	---	<b>See NOTE 1</b>
	Scheduler:	Enable scheduler of load 1	0	---	0: NO  1: YES
	Preopening:	Preopening of load 1	0	min	0...120
	Postclosing:	Postclosing of load 1	0	min	0...120
---	Behaviour load 1 in pause between time bands	0	---	0: OFF BETWEEN BANDS 1: ON BETWEEN BANDS 2: PRE-POST BETWEEN BANDS	
---	Cut load	Enable cut of load 1	0	---	0: NO  1: YES
E03	Switch-OFF for:	Priority to cut the load 1	1	---	1...Max cut load
E04 (if enable cut load)	Lights 1	Label of load 1	---	---	<b>See NOTE 1</b>
	Min time to cut load:	Minimum time for cut load 1	5	sec	0...500
	Max time to cut:	Maximum time that the load is forced OFF	30	sec	0...999
...	...	...	...	...	...

Mask index	Display descript.	Description	Def.	UoM	Values
<b>F. Language</b>					
F01	---	Current language index	0	---	EN/IT/FR
	Enter to change	ENTER to change / Esc to confirm	---	---	
F02	---	Countdown time	60	---	0..999
	User:	New service password	1234	---	0..9999
F03	Installer:	New Installer password	1234	---	0..9999
	Delete data logger:	Reset data logger	0	---	0: NO   1: YES
F04	ModBus for devices Speed:	Baudrate of modbus master protocol	3	---	0: 1200   3: 9600 1: 2400   4: 19200 2: 4800
	Stop bit:	Stop bits of modbus master protocol	1	---	0: 1   1: 2
	Parity:	Parity mode of modbus master protocol	0	---	0: NO   2: ODD 1: EQUAL
	Timeout:	Timeout of modbus master protocol	300	ms	100..5000
F05	BMS1 setting BMS protocol:	Protocol BMS setting (1: CAREL RS485; 2: ModBus RS485; 3: pCOload local)	1	---	0: NONE 1: CAREL RS485 2: MODBUS RS485 3: pCO MANAGER
	Velocità BMS:	Setting BMS speed	4	---	0: 1200   3: 9600 1: 2400   4: 19200 2: 4800
F06	Adress:	Address of the controller in a supervisory system network n.1	1	---	1..207
	BMS2 setting BMS protocol:	Protocol BMS setting (1: CAREL RS485; 2: ModBus RS485; 3: pCOload local)	1	---	0: NONE 1: CAREL RS485 2: MODBUS RS485 3: pCO MANAGER
	BMS speed:	Setting BMS speed	4	---	0: 1200   3: 9600 1: 2400   4: 19200 2: 4800
F07, F08	Address:	Address of the controller in a supervisory system network n.2	1	---	1..207
		Information of pLoads	---	---	

Mask index	Display descript.	Description	Def.	UoM	Values
<b>Logout</b>					
	Level:	Show the user level of unit	---	---	0: None   2: Installer 1: User
	Press Enter to logout	Show the information	-----	---	



**Nota 1:**

- |                      |                          |                          |                     |                  |
|----------------------|--------------------------|--------------------------|---------------------|------------------|
| 0: lights 1          | 10: automatic door 1     | 20: LT Compressor rack 2 | 30: Oven 3          | 40: Warm banch 2 |
| 1: lights 2          | 11: automatic door 2     | 21: NT Compressor rack 1 | 31: Fryer 1         | 41: Others 1     |
| 2: lights 3          | 12: automatic door 3     | 22: NT Compressor rack 2 | 32: Fryer 2         | 42: Others 2     |
| 3: lights 4          | 13: LT Cabinet 1         | 23: Banner 1             | 33: Fryer 3         | 43: Others 3     |
| 4: external lights 1 | 14: LT Cabinet 2         | 24: Banner 2             | 34: Spits 1         | 44: Others 4     |
| 5: external lights 2 | 15: LT Cabinet 3         | 25: Parking outside      | 35: Spits 2         | 45: Others 5     |
| 6: external lights 3 | 16: NT Cabinet 1         | 26: Parking              | 36: Hot-Plate 1     |                  |
| 7: conditioning 1    | 17: NT Cabinet 2         | 27: Covered parking      | 37: Hot-Plate 2     |                  |
| 8: conditioning 2    | 18: NT Cabinet 3         | 28: Oven 1               | 38: Lift recharge 1 |                  |
| 9: conditioning 3    | 19: LT Compressor rack 1 | 29: Oven 2               | 39: Warm banch 1    |                  |



**Nota 2:**

- |             |                     |                  |                       |
|-------------|---------------------|------------------|-----------------------|
| 0: Disabled | 2: ON by scheduler  | 4: ON by manual  | 6: ON by supervision  |
| 1: Cut      | 3: OFF by scheduler | 5: OFF by manual | 7: OFF by supervision |



**Nota 3:**

- |                  |                          |                   |                  |
|------------------|--------------------------|-------------------|------------------|
| 0: IME Nemo 96HD | 2: Ducati Energia Smart+ | 4: Socomec        | 6: CAREL emeter3 |
| 1: IME Nemo D4   | 3: Gavazzi CPT/WM14-DIN  | 5: Electrex Femto |                  |

10. SUPERVISOR TABLE

The table below shows the variables sent to the supervisor.

Analogue variables

Modbus® address	Carel address	Description	UOM	R/W
1	1	Energy meter 1 (Building consumption), Equivalent power	kW	R
2	2	Energy meter 2, Equivalent power	kW	R
3	3	Energy meter 3, Equivalent power	kW	R
4	4	Energy meter 4, Equivalent power	kW	R
5	5	Energy meter 5, Equivalent power	kW	R
6	6	Energy meter 6, Equivalent power	kW	R
7	7	Energy meter 7, Equivalent power	kW	R
8	8	Energy meter 8, Equivalent power	kW	R
9	9	Energy meter 9, Equivalent power	kW	R
10	10	Energy meter 10, Equivalent power	kW	R
11	11	Energy meter 11, Equivalent power	kW	R
12	12	Energy meter 12, Equivalent power	kW	R
13	13	Energy meter 1 (Building consumption), Current line 1	A	R
14	14	Energy meter 2, Current line 1	A	R
15	15	Energy meter 3, Current line 1	A	R
16	16	Energy meter 4, Current line 1	A	R
17	17	Energy meter 5, Current line 1	A	R
18	18	Energy meter 6, Current line 1	A	R
19	19	Energy meter 7, Current line 1	A	R
20	20	Energy meter 8, Current line 1	A	R
21	21	Energy meter 9, Current line 1	A	R
22	22	Energy meter 10, Current line 1	A	R
23	23	Energy meter 11, Current line 1	A	R
24	24	Energy meter 12, Current line 1	A	R
25	25	Energy meter 1 (Building consumption), Current line 2	A	R
26	26	Energy meter 2, Current line 2	A	R
27	27	Energy meter 3, Current line 2	A	R
28	28	Energy meter 4, Current line 2	A	R
29	29	Energy meter 5, Current line 2	A	R
30	30	Energy meter 6, Current line 2	A	R
31	31	Energy meter 7, Current line 2	A	R
32	32	Energy meter 8, Current line 2	A	R
33	33	Energy meter 9, Current line 2	A	R
34	34	Energy meter 10, Current line 2	A	R
35	35	Energy meter 11, Current line 2	A	R
36	36	Energy meter 12, Current line 2	A	R
37	37	Energy meter 1 (Building consumption), Current line 3	A	R
38	38	Energy meter 2, Current line 3	A	R
39	39	Energy meter 3, Current line 3	A	R
40	40	Energy meter 4, Current line 3	A	R
41	41	Energy meter 5, Current line 3	A	R
42	42	Energy meter 6, Current line 3	A	R
43	43	Energy meter 7, Current line 3	A	R
44	44	Energy meter 8, Current line 3	A	R
45	45	Energy meter 9, Current line 3	A	R
46	46	Energy meter 10, Current line 3	A	R
47	47	Energy meter 11, Current line 3	A	R
48	48	Energy meter 12, Current line 3	A	R
49	49	Energy meter 1 (Building consumption), Power factor	---	R
50	50	Energy meter 2, Power factor	---	R
51	51	Energy meter 3, Power factor	---	R
52	52	Energy meter 4, Power factor	---	R
53	53	Energy meter 5, Power factor	---	R
54	54	Energy meter 6, Power factor	---	R
55	55	Energy meter 7, Power factor	---	R
56	56	Energy meter 8, Power factor	---	R
57	57	Energy meter 9, Power factor	---	R
58	58	Energy meter 10, Power factor	---	R
59	59	Energy meter 11, Power factor	---	R
60	60	Energy meter 12, Power factor	---	R

Modbus® address	Carel address	Description	UOM	R/W
61	61	Starting of Time Band 1, full day 1	min	R/W
62	62	Ending of Time Band 1, full day 1	min	R/W
63	63	Starting of Time Band 2, full day 1	min	R/W
64	64	Ending of Time Band 2, full day 1	min	R/W
65	65	Starting of Time Band 1, full day 2	min	R/W
66	66	Ending of Time Band 1, full day 2	min	R/W
67	67	Starting of Time Band 2, full day 2	min	R/W
68	68	Ending of Time Band 2, full day 2	min	R/W
69	69	Starting, reduce day 1	min	R/W
70	70	Ending reduced day 1	min	R/W
71	71	Energy meter 1 (main), Phase to phase voltage L1-L2	V	R
72	72	Energy meter 1 (main), Phase to phase voltage L2- L3	V	R
73	73	Energy meter 1 (main), Phase to phase voltage L3-L1	V	R
74	74	Ending of Time Band 2, full day 2	V	R
75	75	Energy meter 2, Voltage L2-L3	V	R
76	76	Energy meter 2, Voltage L3-L1	V	R
77	77	Energy meter 3, Voltage L1-L2	V	R
78	78	Energy meter 3, Voltage L2-L3	V	R
79	79	Energy meter 3, Voltage L3-L1	V	R
80	80	Energy meter 4, Voltage L1-L2	V	R
81	81	Energy meter 4, Voltage L2-L3	V	R
82	82	Energy meter 4, Voltage L3-L1	V	R
83	83	Energy meter 5, Voltage L1-L2	V	R
84	84	Energy meter 5, Voltage L2-L3	V	R
85	85	Energy meter 5, Voltage L3-L1	V	R
86	86	Energy meter 6, Voltage L1-L2	V	R
87	87	Energy meter 6, Voltage L2-L3	V	R
88	88	Energy meter 6, Voltage L3-L1	V	R
89	89	Energy meter 7, Voltage L1-L2	V	R
90	90	Energy meter 7, Voltage L2-L3	V	R
91	91	Energy meter 7, Voltage L3-L1	V	R
92	92	Energy meter 8, Voltage L1-L2	V	R
93	93	Energy meter 8, Voltage L2-L3	V	R
94	94	Energy meter 8, Voltage L3-L1	V	R
95	95	Energy meter 9, Voltage L1-L2	V	R
96	96	Energy meter 9, Voltage L2-L3	V	R
97	97	Energy meter 9, Voltage L3-L1	V	R
98	98	Energy meter 10, Voltage L1-L2	V	R
99	99	Energy meter 10, Voltage L2-L3	V	R
100	100	Energy meter 10, Voltage L3-L1	V	R
101	101	Energy meter 11, Voltage L1-L2	V	R
102	102	Energy meter 11, Voltage L2-L3	V	R
103	103	Energy meter 11, Voltage L3-L1	V	R
104	104	Energy meter 12, Voltage L1-L2	V	R
105	105	Energy meter 12, Voltage L2-L3	V	R
106	106	Energy meter 12, Voltage L3-L1	V	R
107	107	Energy meter 1 (Building consumption), Phase-neutral average voltage	V	R
108	108	Energy meter 2, Phase-neutral average voltage	V	R
109	109	Energy meter 3, Phase-neutral average voltage	V	R
110	110	Energy meter 4, Phase-neutral average voltage	V	R
111	111	Energy meter 5, Phase-neutral average voltage	V	R
112	112	Energy meter 6, Phase-neutral average voltage	V	R
113	113	Energy meter 7, Phase-neutral average voltage	V	R
114	114	Energy meter 8, Phase-neutral average voltage	V	R
115	115	Energy meter 9, Phase-neutral average voltage	V	R
116	116	Energy meter 10, Phase-neutral average voltage	V	R
117	117	Energy meter 11, Phase-neutral average voltage	V	R
118	118	Energy meter 12, Phase-neutral average voltage	V	R
119	119	Energy meter 1 (Building consumption), Apparent power	kVA	R
120	120	Energy meter 2, Apparent power	kVA	R
121	121	Energy meter 3, Apparent power	kVA	R
122	122	Energy meter 4, Apparent power	kVA	R
123	123	Energy meter 5, Apparent power	kVA	R
124	124	Energy meter 6, Apparent power	kVA	R
125	125	Number of pulse counter	-	R
126	126	Power load 1	kW	R
127	127	Energy meter 7, Apparent power	kVA	R



Modbus® address	Carel address	Description	UOM	R/W
128	128	Energy meter 8, Apparent power	kVA	R
129	129	Energy meter 9, Apparent power	kVA	R
130	130	Energy meter 10, Apparent power	kVA	R
131	131	Energy meter 11, Apparent power	kVA	R
132	132	Energy meter 12, Apparent power	kVA	R
133	133	Percentage to the threshold of apparent power	-	R
134	134	Power load 2	kW	R
135	135	Percentage to cut loads for apparent power	-	R
136	136	Threshold 5 to cut the load for general power	kW	R/W
137	137	Threshold 6 to cut the load for general power	kW	R/W
138	138	Threshold 2 to cut the loads for energy	kW	R/W
139	139	Threshold 3 to cut the loads for energy	kW	R/W
140	140	Threshold 4 to cut the loads for energy	kW	R/W
141	141	Threshold 5 to cut the loads for energy	kW	R/W
142	142	Power load 3	kW	R
143	143	Threshold 6 to cut the loads for energy	kWh	R/W
144	144	Threshold 1 to cut the loads for apparent power	kVA	R/W
145	145	Threshold 2 to cut the loads for apparent power	kVA	R/W
146	146	Threshold 3 to cut the loads for apparent power	kVA	R/W
147	147	Threshold 4 to cut the loads for apparent power	kVA	R/W
148	148	Threshold 5 to cut the loads for apparent power	kVA	R/W
149	149	Threshold 6 to cut the loads for apparent power	kVA	R/W
150	150	Power load 4	kW	R
...	...	...	...	...
158	158	Power load 5	kW	R
...	...	...	...	...
166	166	Power load 6	kW	R
167	167	Energy meter 1, Frequency	Hz	R
168	168	Number of load reading from AIN	-	R/W
...	...	...	...	...
170	170	Label load 1	-	R/W
171	171	Label load 2	-	R/W
172	172	Label load 3	-	R/W
173	173	Label load 4	-	R/W
174	174	Label load 5	-	R/W
175	175	Label load 6	-	R/W
176	176	Label load 7	-	R/W
177	177	Label load 8	-	R/W
178	178	Label load 9	-	R/W
179	179	Label load 10	-	R/W
180	180	Label load 11	-	R/W
181	181	Label load 12	-	R/W
...	...	...	...	...
190	190	Type of device on pLoads Large DIN 17 (0: energy 1: water 2:gas)	-	R/W
191	191	Type of device on pLoads Large DIN 18 (0: energy 1: water 2:gas)	-	R/W
192	192	Type of device on pLoads (CI01-ID1)1 (0: energy 1: water 2:gas)	-	R/W
193	193	Type of device on pLoads (CI01-ID2) (0: energy 1: water 2:gas)	-	R/W
194	194	Type of device on pLoads (CI02-ID1) (0: energy 1: water 2:gas)	-	R/W
195	195	Type of device on pLoads (CI02-ID2) (0: energy 1: water 2:gas)	-	R/W
196	196	Manual of the load 1 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
197	197	Manual of the load 2 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
198	198	Manual of the load 3 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
199	199	Manual of the load 4 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
200	200	Manual of the load 5 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
201	201	Manual of the load 6 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
202	202	Manual of the load 7 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
203	203	Manual of the load 8 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
204	204	Manual of the load 9 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
205	205	Manual of the load 10 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
206	206	Manual of the load 11 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W
207	207	Manual of the load 12 from SPV (0: Auto; 1: OFF; 2: ON)	-	R/W

Tab. 10.a

## Integer variables

Modbus® address	Carel address	Description	UOM	R/W
5001	1	Energy meter 1 (Building consumption), Equivalent energy	kWh	R
5002	2	Energy meter 1 (Building consumption), Equivalent energy	kWh	R
5003	3	Energy meter 2, Equivalent energy	kWh	R
5004	4	Energy meter 2, Equivalent energy	kWh	R
5005	5	Energy meter 3, Equivalent energy	kWh	R
5006	6	Energy meter 3, Equivalent energy	kWh	R
5007	7	Energy meter 4, Equivalent energy	kWh	R
5008	8	Energy meter 4, Equivalent energy	kWh	R
5009	9	Energy meter 5, Equivalent energy	kWh	R
5010	10	Energy meter 5, Equivalent energy	kWh	R
5011	11	Energy meter 6, Equivalent energy	kWh	R
5012	12	Energy meter 6, Equivalent energy	kWh	R
5013	13	Energy meter 7, Equivalent energy	kWh	R
5014	14	Energy meter 7, Equivalent energy	kWh	R
5015	15	Energy meter 8, Equivalent energy	kWh	R
5016	16	Energy meter 8, Equivalent energy	kWh	R
5017	17	Energy meter 9, Equivalent energy	kWh	R
5018	18	Energy meter 9, Equivalent energy	kWh	R
5019	19	Energy meter 10, Equivalent energy	kWh	R
5020	20	Energy meter 10, Equivalent energy	kWh	R
5021	21	Energy meter 11, Equivalent energy	kWh	R
5022	22	Energy meter 11, Equivalent energy	kWh	R
5023	23	Energy meter 2, Equivalent energy	kWh	R
5024	24	Energy meter 2, Equivalent energy	kWh	R
5025	25	Current hour	h	R/W
5026	26	Current minute	min	R/W
5027	27	Current day	day	R/W
5028	28	Current month	month	R/W
5029	29	Current year	year	R/W
5030	30	Starting of Time Band 1, full day 1	h	R/W
5031	31	Ending of Time Band 1, full day 1	h	R/W
5032	32	Starting of Time Band 2, full day 1	h	R/W
5033	33	Ending of Time Band 2, full day 1	h	R/W
5034	34	Starting of Time Band 1, full day 2	h	R/W
5035	35	Ending of Time Band 1, full day 2	h	R/W
5036	36	Starting of Time Band 2, full day 2	h	R/W
5037	37	Ending of Time Band 2, full day 2	h	R/W
5038	38	Starting, reduce day 1	h	R/W
5039	39	Ending reduced day 1	h	R/W
5040	40	Type scheduler Monday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5041	41	Type scheduler Tuesday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5042	42	Type scheduler Wednesday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5043	43	Type scheduler Thursday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5044	44	Type scheduler Friday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5045	45	Type scheduler Saturday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5046	46	Type scheduler Sunday (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5047	47	Day-Month start special period 1	---	R/W
5048	48	Day-Month end special period 1	---	R/W
5049	49	Behavior in special period 1 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5050	50	Day-Month start special period 2	---	R/W
5051	51	Day-Month end special period 2	---	R/W
5052	52	Behavior in special period 2 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5053	53	Day-Month start special period 3	---	R/W
5054	54	Day-Month end special period 3	---	R/W
5055	55	Behavior in special period 3 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5056	56	Day-Month start special period 4	---	R/W
5057	57	Day-Month end special period 4	---	R/W
5058	58	Behavior in special period 4 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5059	59	Day-Month start special period 5	---	R/W
5060	60	Day-Month end special period 5	---	R/W
5061	61	Behavior in special period 5 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5062	62	Day-Month start special period 6	---	R/W
5063	63	Day-Month end special period 6	---	R/W
5064	64	Behavior in special period 6 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5065	65	Day-Month start special period 7	---	R/W

Modbus® address	Carel address	Description	UOM	R/W
5066	66	Day-Month end special period 7	---	R/W
5067	67	Behavior in special period 7 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5068	68	Day-Month start special period 8	---	R/W
5069	69	Day-Month end special period 8	---	R/W
5070	70	Behavior in special period 8 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5071	71	Day-Month start special period 9	---	R/W
5072	72	Day-Month end special period 9	---	R/W
5073	73	Behavior in special period 9 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5074	74	Day-Month start special period 10	---	R/W
5075	75	Day-Month end special period 10	---	R/W
5076	76	Behavior in special period 10 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5077	77	Day-Month start special period 11	---	R/W
5078	78	Day-Month end special period 11	---	R/W
5079	79	Behavior in special period 11 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5080	80	Day-Month start special period 12	---	R/W
5081	81	Day-Month end special period 12	---	R/W
5082	82	Behavior in special period 12 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5083	83	Day-Month start special period 13	---	R/W
5084	84	Day-Month end special period 13	---	R/W
5085	85	Behavior in special period 13 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5086	86	Day-Month start special period 14	---	R/W
5087	87	Day-Month end special period 14	---	R/W
5088	88	Behavior in special period 14 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5089	89	Day-Month start special period 15	---	R/W
5090	90	Day-Month end special period 15	---	R/W
5091	91	Behavior in special period 15 (0= full; 1= special; 2=reduce; 3= closed)	---	R/W
5092	92	Preopening of load 1	min	R/W
5093	93	Postclosing of load 1	min	R/W
5094	94	Behaviour load 1 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5095	95	Priority to cut the load 1	---	R/W
5096	96	Preopening of load 2	min	R/W
5097	97	Postclosing of load 2	min	R/W
5098	98	Behaviour load 2 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5099	99	Priority to cut the load 2	---	R/W
5100	100	Preopening of load 3	min	R/W
5101	101	Postclosing of load 3	min	R/W
5102	102	Behaviour load 3 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5103	103	Priority to cut the load 3	---	R/W
5104	104	Preopening of load 4	min	R/W
5105	105	Postclosing of load 4	min	R/W
5106	106	Behaviour load 4 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5107	107	Priority to cut the load 4	---	R/W
5108	108	Preopening of load 5	min	R/W
5109	109	Postclosing of load 5	min	R/W
5110	110	Behaviour load 5 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5111	111	Priority to cut the load 5	---	R/W
5112	112	Preopening of load 6	min	R/W
5113	113	Postclosing of load 6	min	R/W
5114	114	Behaviour load 6 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5115	115	Priority to cut the load 6	---	R/W
5116	116	Priority to cut the load 6	min	R/W
5117	117	Postclosing of load 7	min	R/W
5118	118	Behaviour load 7 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5119	119	Priority to cut the load 7	---	R/W
5120	120	Preopening of load 8	min	R/W
5121	121	Postclosing of load 8	min	R/W
5122	122	Behaviour load 8 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5123	123	Priority to cut the load 8	---	R/W
5124	124	Preopening of load 9	min	R/W
5125	125	Postclosing of load 9	min	R/W
5126	126	Behaviour load 9 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5127	127	Priority to cut the load 9	---	R/W
5128	128	Preopening of load 10	min	R/W
5129	129	Postclosing of load 10	min	R/W
5130	130	Behaviour load 10 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5131	131	Priority to cut the load 10	---	R/W
5132	132	Preopening of load 11	min	R/W

Modbus® address	Carel address	Description	UOM	R/W
5133	133	Postclosing of load 11	min	R/W
5134	134	Behaviour load 11 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5135	135	Priority to cut the load 11	---	R/W
5136	136	Preopening of load 12	min	R/W
5137	137	Postclosing of load 12	min	R/W
5138	138	Behaviour load 12 in pause between TB (0: Load OFF; 1: Load ON; 2: AUTO)	---	R/W
5139	139	Priority to cut the load 12	---	R/W
5140	140	Threshold 1 to cut the loads for general power	KW	R/W
5141	141	Threshold 2 to cut the loads for general power	kW	R/W
5142	142	Threshold 3 to cut the loads for general power	kW	R/W
5143	143	Threshold 4 to cut the loads for general power	kW	R/W
5144	144	Percentage to cut loads for power	---	R/W
5145	145	Threshold 1 to cut the loads for energy	kWh	R/W
5146	146	Time to check the energy	min	R/W
5147	147	Percentage to cut loads for energy	---	R/W
5148	148	Delay between different cut	min	R/W
5149	149	Min time for cut load 1	min	R/W
5150	150	Max time for cut load 1	min	R/W
5151	151	Pulse counter B5: pLoads Large – ID1: pLoads Compact (high part)	---	R
5152	152	Pulse counter B5: pLoads Large – ID1: pLoads Compact (low part)	---	R
5153	153	Type of period for next event	---	R
5154	154	SW version	---	R
5155	155	SW date	---	R
5156	156	Pulse counter from CI 1 digital input 1 (high part)	---	R
5157	157	Pulse counter from CI 1 digital input 1 (low part)	---	R
5158	158	Pulse counter from CI 1 digital input 2 (high part)	---	R
5159	159	Pulse counter from CI 1 digital input 2 (low part)	---	R
5160	160	Pulse counter from CI 2 digital input 1 (high part)	---	R
5161	161	Pulse counter from CI 2 digital input 1 (low part)	---	R
5162	162	Pulse counter from CI 2 digital input 2 (high part)	---	R
5163	163	Pulse counter from CI 2 digital input 2 (low part)	---	R
5164	164	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>Δ</sup> Pulse_Conversion , CI 1 ID1 (see note 3)	---	R
5165	165	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>Δ</sup> Pulse_Conversion , CI 1 ID2 (see note 3)	---	R
5166	166	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>Δ</sup> Pulse_Conversion CI 2 ID1 (see note 3)	---	R
5167	167	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>Δ</sup> Pulse_Conversion CI 2 ID2 (see note 3)	---	R
5168	168	Energy of aux load 1	---	R/W
5169	169	Energy of aux load 1	---	R/W
5170	170	Energy of aux load 2	---	R/W
5171	171	Energy of aux load 2	---	R/W
5172	172	Energy of aux load 3	---	R/W
5173	173	Energy of aux load 3	---	R/W
5174	174	Energy of aux load 4	---	R/W
5175	175	Energy of aux load 4	---	R/W
5176	176	Energy of aux load 5	---	R/W
5177	177	Energy of aux load 5	---	R/W
5178	178	Energy of aux load 6	---	R/W
5179	179	Energy of aux load 6	---	R/W
5180	180	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>Δ</sup> Pulse_Conversion (B5: pLoads Large – ID1: pLoads ompact) (see note 3)	---	R
5181	181	Status of load 1 (see note 2)	---	R
5182	182	Status of load 2 (see note 2)	---	R
5183	183	Status of load 3 (see note 2)	---	R
5184	184	Status of load 4 (see note 2)	---	R
5185	185	Status of load 5 (see note 2)	---	R
5186	186	Status of load 6 (see note 2)	---	R
5187	187	Status of load 7 (see note 2)	---	R
5188	188	Status of load 8 (see note 2)	---	R
5189	189	Status of load 9 (see note 2)	---	R
5190	190	Status of load 10 (see note 2)	---	R
5191	191	Status of load 11 (see note 2)	---	R
5192	192	Status of load 12 (see note 2)	---	R
5193	193	Type of device on pLoads (Fast DIN) (0: Energy; 1: Water; 2: Gas)	---	R/W
5194	194	Type day active	---	R

Modbus® address	Carel address	Description	UOM	R/W
5195	195	Day of next event	---	R
5196	196	Month of next event	---	R
5197	197	PPercentage to the threshold of power	---	R
5198	198	Percentage to the threshold of energy	---	R
5199	199	Number of energy meter in Modbus®	---	R/W
5200	200	Loads number	---	R/W
5201	201	Pulse counter ID17 pLoads Large, with PCO208DI00 (high part)	---	R
5202	202	Pulse counter ID17 pLoads Large, with PCO208DI00 (low part)	---	R
5203	203	Pulse counter ID18 pLoads Large, with PCO208DI00 (high part)	---	R
5204	204	Pulse counter ID18 pLoads Large, with PCO208DI00 (low part)	---	R
5205	205	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>^</sup> Pulse_Conversion (X8X), Pulse counter from ID17 (see note 3)	---	R/W
5206	206	"Pulse_Conversion"; The value of the counter is according with formula: Value= pulse x 10 <sup>^</sup> Pulse_Conversion (X8X), Pulse counter from ID18 (see note 3)	---	R/W
---	---	----	---	---

Tab. 10.b



### Note 1:

0: lights 1	10: automatic door 1	20: lt compressor rack 2	30: oven 3	40: warm banch 2
1: lights 2	11: automatic door 2	21: nt compressor rack 1	31: fryer 1	41: others 1
2: lights 3	12: automatic door 3	22: nt compressor rack 2	32: fryer 2	42: others 2
3: lights 4	13: lt cabinet 1	23: banner 1	33: fryer 3	43: others 3
4: external lights 1	14: lt cabinet 2	24: banner 2	34: spits 1	44: others 4
5: external lights 2	15: lt cabinet 3	25: parking outside	35: spits 2	45: others 5
6: external lights 3	16: nt cabinet 1	26: parking	36: hot-plate 1	
7: conditioning 1	17: nt cabinet 2	27: overed parking	37: hot-plate 2	
8: conditioning 2	18: nt cabinet 3	28: oven 1	38: lift recharge 1	
9: conditioning 3	19: lt compressor rack 1	29: oven 2	39: warm banch 1	



### Note 2:

0: disabled	2: ON by scheduler	4: Manual ON	6: ON by supervisor	8: Waiting timings between loads
1: cut	3: OFF by scheduler	5: Manual OFF	7: OFF by supervisor	



### Note 3:

0: 1	2: 100	4: 10000	6: 0,1
1: 10	3: 1000	5: 100000	

## Digital variables

Modbus® address	Carel address	Description	UdM	R/W
1	1	General alarm	---	R
2	2	pLoads Large	----	R
3	3	ALARM probe B1	---	R
4	4	ALARM probe B2	----	R
5	5	ALARM probe B3	----	R
6	6	ALARM probe B6	----	R
7	7	ALARM probe B7	----	R
8	8	ALARM probe B8	----	R
9	9	Enable cut loads by power	----	R/W
10	10	Enable cut loads by apparent power	----	R/W
11	11	Enable cut loads by energy	----	R/W
...	...	...	---	---
15	15	Reset energy of aux load 1	----	R/W
16	16	Reset energy of aux load 2	----	R/W
17	17	Reset energy of aux load 3	----	R/W
18	18	Reset energy of aux load 4	----	R/W
19	19	Reset energy of aux load 5	----	R/W
20	20	Reset energy of aux load 6	----	R/W
...	...	...	---	---
27	27	Energy meter 1 (Building consumption), Reset energy	----	R/W
28	28	Energy meter 2, Reset energy	----	R/W
29	29	Energy meter 3, Reset energy	----	R/W
30	30	Energy meter 4, Reset energy	----	R/W
31	31	Energy meter 5, Reset energy	----	R/W
32	32	Energy meter 6, Reset energy	----	R/W
33	33	Energy meter 7, Reset energy	----	R/W
34	34	Energy meter 8, Reset energy	----	R/W
35	35	Energy meter 9, Reset energy	----	R/W
36	36	Energy meter 10, Reset energy	----	R/W
37	37	Energy meter 11, Reset energy	----	R/W
38	38	Energy meter 12, Reset energy	----	R/W
39	39	Enable scheduler of load 1	----	R/W
40	40	Enable cut of load 1	----	R/W
41	41	Enable scheduler of load 2	----	R/W
42	42	Enable cut of load 2	----	R/W
43	43	Enable scheduler of load 3	----	R/W
44	44	Enable cut of load 3	----	R/W
45	45	Enable scheduler of load 4	----	R/W
46	46	Enable cut of load 4	----	R/W
47	47	Enable scheduler of load 5	----	R/W
48	48	Enable cut of load 5	----	R/W
49	49	Enable scheduler of load 6	----	R/W
50	50	Enable cut of load 6	----	R/W
51	51	Enable scheduler of load 7	----	R/W
52	52	Enable cut of load 7	----	R/W
53	53	Enable scheduler of load 8	----	R/W
54	54	Enable cut of load 8	----	R/W
55	55	Enable scheduler of load 9	----	R/W
56	56	Enable cut of load 9	----	R/W
57	57	Enable scheduler of load 10	----	R/W
58	58	Enable cut of load 10	----	R/W
59	59	Enable scheduler of load 11	----	R/W
60	60	Enable cut of load 11	----	R/W
61	61	Enable scheduler of load 12	----	R/W
62	62	Enable cut of load 12	----	R/W
63	63	ALARM blackout of fast Din (pLoads Large: B5; pLoads Compact: ID1)	----	R
64	64	Status load 1	----	R
65	65	ALARM clock board	----	R
66	66	Status load 2	----	R
67	67	ALARM P-memory (internal error)'	----	R
68	68	Status load 3	----	R
69	69	ALARM off-line, energy meter 1, add 2	----	R
70	70	Status load 4	----	R
71	71	ALARM offline energy meter 2 add.3	----	R
72	72	Status load 5	----	R

Modbus* address	Carel address	Description	UdM	R/W
73	73	ALARM offline energy meter 3 add.4	---	R
74	74	Status load 6	---	R
75	75	ALARM offline energy meter 4 add.5	---	R
76	76	Status load 7	---	R
77	77	ALARM offline energy meter 5 add.6	---	R
78	78	Status load 8	---	R
79	79	ALARM offline energy meter 6 add.7	---	R
80	80	Status load 9	---	R
81	81	ALARM offline energy meter 7 add.8	---	R
82	82	Status load 10	---	R
83	83	ALARM offline energy meter 8 add.9	---	R
84	84	Status load 11	---	R
85	85	ALARM offline energy meter 9 add.10	---	R
86	86	Status load 12	---	R
87	87	Status of digital input remote ON-OFF	---	R
88	88	IN 1 for band of energy/power	---	R
89	89	IN 2 for band of energy/power	---	R
90	90	Status of digital input load by-passed	---	R
91	91	RESET ALLARM	---	R/W
92	92	Building ON-OFF	---	R/W
93	93	On-Off building (0: Off; 1: On)	---	R
94	94	ALARM offline energy meter 10 add.11	---	R
95	95	ALARM offline energy meter 11 add.12	---	R
96	96	ALARM offline energy meter 12 add.13	---	R
97	97	ALARM Load by-passed	---	R
98	98	CI address 31 present	---	R
99	99	CI address 32 present	---	R
100	100	Board is pCO compact	---	R
101	101	ALARM blackout (ID17)	---	R
102	102	ALARM blackout (ID18)	---	R
103	103	ALARM offline AccessPoint (address 1)	---	R
104	104	ALARM offline CI (address 31)	---	R
105	105	ALARM offline CI (address 32)	---	R
106	106	ALARM low battery CI (address 31)	---	R
107	107	ALARM low battery CI (address 32)	---	R

Tab. 10.c

## 11. ALARM TABLE

Alarm code	Display / Description	Reset	Action	Alarm relay
AL01	Clock card error or not connected	Manual	No	YES
AL02	Extended memory error	Manual	No	YES
AL03	Load bypassed	Automatic	No	YES
AL04	Set counter manually	Manual	No	YES
AL05	Energy meter 1 offline	Automatic	Load cut-off disabled	YES
AL06	Energy meter 2 offline	Automatic	No	YES
AL07	Energy meter 3 offline	Automatic	No	YES
AL08	Energy meter 4 offline	Automatic	No	YES
AL09	Energy meter 5 offline	Automatic	No	YES
AL10	Energy meter 6 offline	Automatic	No	YES
AL11	Energy meter 7 offline	Automatic	No	YES
AL12	Energy meter 8 offline	Automatic	No	YES
AL13	Energy meter 9 offline	Automatic	No	YES
AL14	Energy meter 10 offline	Automatic	No	YES
AL15	Energy meter 11 offline	Automatic	No	YES
AL16	Energy meter 12 offline	Automatic	No	YES
AL17	Probe B1 fault	Automatic	No	YES
AL18	Probe B2 fault	Automatic	No	YES
AL19	Probe B3 fault	Automatic	No	YES
AL20	Probe B6 fault	Automatic	No	YES
AL21	Probe B7 fault	Automatic	No	YES
AL22	Probe B8 fault	Automatic	No	YES
AL23	Manually set counter ID17	Automatic	No	YES
AL24	Manually set counter ID18	Automatic	No	YES
AL25	Access Point offline/disconnected	Automatic	No	YES
AL26	CI pulse counter add. 31, offline	Automatic	No	YES
AL27	CI pulse counter add. 32, offline	Automatic	No	YES
AL28	CI pulse counter add. 31, general alarm	Automatic	No	YES
AL29	CI pulse counter add. 31, battery discharged	Automatic	No	YES
AL30	CI pulse counter add. 31, general alarm	Automatic	No	YES
AL31	CI pulse counter add. 32, battery discharged	Automatic	No	YES

Tab. 11.a



## 12. PLOADS FEATURES

### 12.1 Installation warnings - intended environments and connection

Avoid installing the boards in environments with the following characteristics:

- relative humidity greater than the 90%;
- strong vibrations or knocks;
- exposure to continuous water sprays and exposure to aggressive and polluting atmospheres (e.g.: sulphur and ammonia fumes, saline mist, smoke) with consequent corrosion and/or oxidation;
- strong magnetic and/or radio frequency interference (therefore avoid installing the units near transmitting antennae);
- exposure to direct sunlight and to the elements in general;
- large and rapid fluctuations in the room temperature;
- environments where explosives or mixes of flammable gases are present;
- exposure to dust (formation of corrosive patina with possible oxidation and reduction of insulation).

The following warnings must be observed for connection:

- install a power supply disconnect device in compliance with standards in force;
- a power supply voltage other than the rated value may seriously damage the system;
- use cable ends suitable for the corresponding terminals. Loosen each screw and insert the cable ends, then tighten the screws. When the operation is completed, slightly tug the cables to check they are sufficiently tight;
- separate as much as possible the probe signal and digital input cables from the cables carrying inductive loads and power cables to avoid possible electromagnetic disturbance. Never insert power cables (including the electrical cables) and probe signal cables in the same conduits. Do not install probe cables in the immediate vicinity of power devices (contactors, circuit breakers or similar);
- reduce the path of probe cables as much as possible, and avoid spiral paths that enclose power devices.
- avoid touching or nearly touching the electronic components fitted on the boards to avoid electrostatic discharges (extremely damaging) from the operator to the components;
- separate the power supply to digital outputs from the power supply to pLoads;
- do not secure the cables to the terminals by pressing the screwdriver with excessive force, to avoid damaging the controller;
- disconnect the controller from the power supply before performing any type of maintenance or assembly operations;
- the controller must be installed inside a panel and must not be accessible, to avoid knocks and bumps;
- if the device is used in a way not specified by the manufacturer, its rated protection may be affected;
- in the event of faults on the controller and the optional cards, only contact CAREL for repairs;
- only fit optional cards and connectors supplied by CAREL.

pLoads does not provide protection against short-circuits and overloads, consequently suitable protection devices must be installed on the power supply lines (2.5 AT fuses) and 230 Vac digital input lines (500 mA fuses).

pLoads is not a device that guarantees electrical safety, but rather suitable operation: to prevent short-circuits from causing fire in the electrical panels, the customer must install appropriate electromechanical protection devices on the lines in question (fuses or the like). In addition, the type of software does not guarantee electrical safety.

## 12.2 Uploading the application program

---

When a new software release becomes available, the application program can be loaded to the flash memory in different ways:

1. by key:
  - smart key PCOS00AKY0;
  - USB pen drive;
2. by PC:
  - 485 serial port (28.8 kbps and 115.2 kbps) using USB-485 adapter code "CVSTDUTLFO";
  - USB slave.

To upload via PC, the "pCO Manager" manager program is available free-of-charge on the website [ksa.carel.com](http://ksa.carel.com).

### USB port operation

pLoads features two different USB ports (host and slave), to be used during installation and diagnostics.

**Note:** two USB ports can not be used simultaneously and have different capabilities. Otherwise the right functioning of pLoads, is not assured.

The host port can be connected to USB storage devices (pendrive, portable hard disk, etc. with maximum current 200 mA) for performing a series of operations:

- upload to pLoads files in the removable drive: application, parameters in buffer memory, configuration files for logs, BIOS.
- download files from pLoads to the removable drive: application, parameters in buffer memory, data log, BIOS.

To access the menu used to manage the contents of the removable drive connected to the host port, simply hold ALARM+ENTER for a few seconds, until the first BIOS system screen is shown. Selecting the FLASH/USB MEMORY item and then USB PEN DRIVE accesses the main menu used to choose the operation, upload or download. When selecting UPLOAD, a further option is shown to specify manual access to the contents of the pen drive (browsing the directories and files) or automatic access (direct access to the configuration files). In addition, if the peripheral connected contains a file called AUTORUN.TXT that is compliant with the corresponding specifications, the terminal will automatically show a screen for the direct activation of the specific function this refers to.

The DOWNLOAD option is used to download the application, the logs, the parameters and the BIOS. Note that during the upload and download procedures through the host port, operation of the pLoads BIOS is limited solely to USB management.

The USB slave port can be connected directly to a PC, without needing additional devices. To use this function, the pCO Manager software is required. The following operations are available through this port

- upload files to pLoads,
- download data to the PC from pLoads,
- manage the NAND flash,
- commissioning.

Applications or BIOS can be uploaded through the slave port. The application includes any files relating to the parameters in the buffer memory and any configuration files for acquiring the logs. The download operations allowed are all those featured in pCO Manager, that is, downloading the logs and the contents of T and P memories.

The slave port connection can also be used to manage the NAND flash, with the possibility to upload/download the files, delete files or completely format the memory. The same port can also be used for commissioning, as long as a suitable application is used, together with the information contained in the .2cf file.

### 12.3 Power supply

A class II safety transformer with a minimum rating of 50 VA and a 2.5 AT fuse must be used in the installation to supply just one pLoads controller. The power supply to the pLoads controller and terminal (or pLoads controllers and terminals) should be separated from the power supply to the other electrical devices (contactors and other electromechanical components) inside the electrical panel. If the secondary of the transformer is earthed, make sure that the earth wire is connected to terminal G0. This is true for all the devices connected to the pLoads. If more than one pLoads controller is connected, make sure that the G and G0 references are observed (G0 must be maintained for all boards).

### 12.4 Technical specifications

#### Physical specifications

	pLoads Compact	pLoads Large
dimensions	all the versions are available on 6 DIN modules, 105x115x60 mm	Large version installable on 18 DIN modules, 110 x 315 x 60 mm
assembly	DIN rail	

Tab. 12.a

#### Plastic case

- Fitted on DIN rail in accordance with DIN 43880 and IEC EN 50022;
- Material: technopolymer;
- Flammability (pLoads Compact): V2 (UL94) and 960°C (IEC 695);
- Flammability (pLoads Large): V2 (UL94) and 850 °C (in accordance with IEC 60695);
- Ball pressure test 125 °C;
- Resistance to creeping current ≥ 250 V
- Colour grey RAL7035

#### Electrical specifications

	pLoads Compact	pLoads Large
DC power supply	48 Vdc (36 Vmin to 72 Vmax)	28 to 36 Vdc +10/-20%
AC power supply	24 Vac +10/-15 %, 50/60 Hz	
Maximum power	14 VA/11 W	45 VA/20 W
CPU	H8SX/1651 32-bit, 50 MHz	
Program memory (FLASH)	2+2 MBytes	
Working cycle duration	average 0.5 s	
Clock	Available as standard and integrated into main board	
Clock precision	100 ppm	
Battery specifications	lithium button battery code CR2430 voltage 3 Vdc (size 24x3 mm)	

Tab. 12.b

#### Analogue inputs

	10 m	
Max. cable length	10-bit A/D converter embedded in CPU	
Analogue conversion	pLoads Compact	pLoads Large
CAREL NTC -50T90 °C; R/T 10 kΩ at 25°C or HT NTC0T150 °C	--	--
0 to 1 Vdc voltage	B1, B2, B3	B1, B2, B3, B6, B7, B8
0 to 5 Vdc ratiometric	B1, B2, B3	B1, B2, B3, B6, B7, B8
0 to 10 Vdc voltage	B1, B2, B3	B1, B2, B3, B6, B7, B8
0 to 20 mA or 4 to 20 mA current	B1, B2	B1, B2, B3, B6, B7, B8
PT1000 -100T200 °C; R/T 1000 Ω at 0 °C	--	--
Classification of measuring circuits (IEC EN 61010-1)	--	--
Total	3	6

Tab. 12.c

**Warning:** the 21 Vdc available at terminal +Vdc (J2) can be used to power any active probes; the maximum current is 60mA for pLoads Compact, 150mA for pLoads Large (protected against short-circuits). To power the 0 to 5 Vdc ratiometric probes, use +5 VREF, maximum current available 60 mA (protected against short-circuits). Only use these voltages to power the active probes connected.

Digital inputs

Max. cable length	10 m	
Type	Not optically-isolated, voltage-free contact	
Power supply	Internal	
	<b>pLoads Compact</b>	<b>pLoads Large</b>
Multifunction analogue inputs	--	--
Fast digital input	ID1 (opto-isolated)	B5 (not opto-isolated)
Normal digital input	1	18
Total	2	18

Tab. 12.d

Warnings:

for DC digital inputs (Vdc), either the + or the - can be connected to the common (IDC1). the rating of the external contact connected to the digital inputs must be at least 5 mA.

Digital outputs

type	pLoads Compact	pLoads Large
maximum number	6	14

To simplify wiring, the common terminals of some relays have been grouped together, depending on the insulation distance. Within a group, the relays only have basic insulation between them and thus must be powered at the same voltage (generally 24 Vac or 110 to 230 Vac). Between groups there is reinforced insulation, thus the groups can be powered at different voltages.

Make sure that the current running through the common terminals does not exceed the rated current of an individual terminal, that is, 8 A. Minimum relay contact current: 50 mA.

Insulation distance The relay outputs have different features, depending on the model of pLoads. The outputs can be divided into groups. Between groups (cells in the table) there is double insulation and consequently these may have different voltages. There is also double insulation between each terminal of the digital outputs and the rest of the controller. The relays belonging to the same group (individual cell in the table) have basic insulation and therefore must have the same power supply (24 or 230 Vac).

Makeup of the groups		group 1	group 2	group 3	group 4	group 5	group 6	group 7	group 8	group 9	group 10
	Large	1-3	4-6	7	8	9-11	12	13	14	15	16-18
	Relay type	Type A	Type A	Type A	Type A	Type A	Type A	Type A	Type A	Type A	Type A
	Compact	1	2	3-7	-	-	-	-	-	-	-
	Relay type	Type A	Type A	Type B	-	-	-	-	-	-	-

Changeover contacts pLoads Large: relays 8, 12, 13, 14 and 15 (total 5)  
pLoads Compact: relay 1 (total 1)

Switchable power type A relay SPDT relay:  
UL873: 2.5 A resistive, 2 A FLA, 12 A LRA, 250 Vac, C300 pilot duty (30,000 cycles)  
EN60730-1: 2 A resistive, 2 A inductive, cos-φ=0.6, 2 (2) A (100,000 cycles)  
type B relay SPST relay:  
UL873: 1 A resistive, 1 A FLA, 6 A LRA, 250 Vac, D300 pilot duty (30,000 cycles)  
EN60730-1: 1 A resistive, 1 A inductive, cos-φ=0.6, 1 (1) A (100,000 cycles)

SSR outputs pLoads Large: relays 7, 12 and 14 or 7, 12, 14 and 15 (total 3 or 4)  
working voltage: 24 Vac/Vdc; maximum power: 10 W, resistive load  
working voltage: 110/230 Vac/Vdc; maximum power: 10 W, resistive load

## 12.5 Other features


Operating conditions	-10T60 °C, 90% RH non-condensing
Storage and transport conditions	-20T70 °C, 90% RH non-condensing
Index of protection	IP40 on the front panel only
Environmental pollution	2
Class according to protection against electric shock	to be integrated into Class I and/or II appliances
Period of stress across the insulating parts	long
Type of action	1 C
Type of disconnection or microswitching	microswitching
Category of resistance to heat and fire	Category D (UL94-V0)
Immunity against voltage surges	Category II
Ageing characteristics (operating hours)	80,000
Number of automatic operating cycles	100,000 (EN 60730-1); 30,000 (UL 873)
Software class and structure	Class A
Category of immunity to voltage surges	Category III (IEC EN 61000-4-5)

Tab. 12.e

The device is not designed to be hand-held.

## Guidelines for disposal

- Do not dispose of the product as municipal waste; it must be disposed of through specialist waste disposal centres.
- The product contains a battery that must be removed and separated from the rest of the product according to the instructions provided, before disposing of the product.
- Improper use or incorrect disposal of the product may have negative effects on human health and on the environment.
- The public or private waste collection systems defined by local legislation must be used for disposal.
- In the event of illegal disposal of electrical and electronic waste, the penalties are specified by local waste disposal legislation.



## 12.6 Dimensions

### pLoads Compact




Fig. 12.a

### pLoads Large




Fig. 12.b

For further information, see the pCO sistema user manual.



# CAREL

**CAREL INDUSTRIES HQs**

Via dell'Industria, 11 - 35020 Brugine - Padova (Italy)  
Tel. (+39) 049.9716611 - Fax (+39) 049.9716600  
e-mail: CAREL@CAREL.com - www.CAREL.com

